

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6TIME 1400LOCATION PS234MDATE 5/22/02PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Outside							
Perimeter Main Entrance		60.0	33.0	551	2	26	0.0
Air Reading In by Main Desk		69.5	32.3	552	2	14	0.0
NW		61.6	27.3	520	2	25	0.0
West		61.8	27.5	518	2	24	0.0
SW		62.1	27.6	523	2	26	0.0
South		62.3	27.8	528	2	28	0.0
SE		62.5	28.0	518	2	25	0.0
Main Entrance		62.9	28.2	510	2	23	0.0
NE		63.3	28.4	501	2	23	0.0
Courtyard		63.6	28.5	499	2	25	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/22/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4TIME 1430LOCATION PS234MDATE 5/22/02PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Cateterium		72.5	24.9	740	0	13	0.0
Gym	1	70.0	31.2	655	0	14	0.0
Hall by Gym		70.3	30.0	696	0	13	0.0
Elevator (Hall)		69.5	30.0	626	0	13	0.0
Hall by Exit 1		68.6	29.7	618	0	14	0.0
114 (Hall)	16	68.0	32.9	940	0	14	0.0
116	14	69.9	34.4	1000	0	14	0.0
118	20	69.9	34.1	1083	0	15	0.0
120	25	69.9	33.1	1001	0	12	0.0
123 (Hall)		69.5	32.8	990	0	13	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/22/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6


TIME 1500

LOCATION PS234M DATE 5/22/02 PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
223		69.7	33.9	853	0	5	n.c.
220		70.8	33.8	875	0	7	n.c.
218		71.8	33.0	865	0	6	n.c.
216		73.1	33.5	884	0	6	n.c.
212 (Hall)		72.9	32.5	844	0	7	n.c.
229		72.5	31.1	840	0	10	n.c.
227 (Hall)		73.0	32.4	886	0	7	n.c.
225		72.8	30.0	856	0	7	n.c.
210		72.6	31.8	841	0	6	n.c.
Stair 1 (with)		71.2	30.1	877	0	8	n.c.
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 5/22/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6TIME 1600LOCATION PS234MDATE 5/22/02PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
301		73.3	28.4	746	1	9	0.0
302 (Hallway)		73.5	27.6	730	1	4	0.0
303		73.0	30.4	860	1	11	0.0
304 (Hall)		73.0	27.3	780	1	11	0.0
311		72.8	27.3	750	1	10	0.0
306		72.5	26.4	756	1	10	0.0
315		73.0	27.2	855	1	8	0.0
308		72.3	26.8	784	1	11	0.0
319		72.6	26.5	811	1	11	0.0
Hall by Elevator		72.4	27.0	795	1	12	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: [Signature] Date: 5/22/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 5TIME 1600LOCATION PS234MDATE 5/22/12 PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
301		73.3	28.4	746	1	9	0.1
302 (Hallway)		73.5	27.6	730	1	10	0.1
303		73.0	30.4	860	1	11	0.1
304 (Hallway)		73.0	27.3	780	1	11	0.1
311		72.8	27.3	750	1	10	0.1
316		72.8	26.4	756	1	10	0.1
315		73.0	27.2	825	1	8	0.1
318		72.3	26.8	784	1	11	0.1
319		72.6	26.5	811	1	11	0.1
Hall by Elevator		72.4	27.0	795	1	12	0.1
Guideline levels ASHRAE/AHIA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____


The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 5/22/12

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6TIME 1630LOCATION PS234MDATE 5/22/02PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
323		72.4	28.4	880	1	11	0.0
Stair 1 (hall)		72.8	27.4	843	1	10	0.0
310 (hall)		72.0	27.4	840	1	9	0.0
325		72.7	28.1	872	1	11	0.0
329		72.6	28.2	820	1	10	0.0
316		72.5	28.5	870	1	11	0.0
318		72.6	28.0	816	1	9	0.0
320		72.8	28.7	810	1	10	0.0
322		73.0	28.6	861	1	12	0.0
Stair 3 (hall)		72.6	28.3	875	1	12	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 5/22/02