

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page of

Time: 7:00 AM

LOCATION: PS 234

DATE: 6/7/02

PROJECT NO:

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
CUTSHEET							
MAIN ENTRANCE	0	58.9	60.1	526	1	14	0
NEXT TO MAIN DESK	0	58.9	60.1	526	1	11	0
NORTHWEST CORNER	0	58.8	60.1	526	1	10	0
WEST SHELF	0	58.9	60.1	518	1	8	0
SOUTHWEST CORNER	0	58.9	60.1	519	1	10	0
COURTYARD	0	58.9	60.1	536	1	10	0
NORTH EAST CORNER	0	58.9	60.1	539	1	9	0
MAIN ENTRANCE	0	58.9	60.1	541	1	11	0
SOUTHEAST CORNER	0	58.9	60.1	550	1	14	0
SOUTH SHELF	0	58.9	60.1	531	1	8	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73 – 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/07/02

CITY_21MC100_002852134

Page of

DATE: 6/7/02 PROJECT NO:

Comments: _____

Date: 6/7/02

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 5 of 10

Time: 1/10 AM LOCATION: P5 234

DATE: 6/7/02 PROJECT NO: _____

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
CITICORP	3	71.6	42.6	641	1	10	0
HALL BY Gym	0	72.6	43.6	541	1	11	0
Gym	0	72.5	43.4	591	1	8	0
MAIN FOYER	3	73.4	43.4	720	1	6	0
MAIN DESK	1	73.4	43.6	716	1	12	0
HALL BY ELEVATOR	0	73.6	43.7	619	1	12	0
HALL BY EXIT 1	0	73.5	43.6	593	1	12	0
HALLWAY 114 NEXT TO Rm	0	73.7	43.4	616	1	11	0
116	0	73.6	43.7	625	1	9	0
110	25	73.7	43.8	601	1	11	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/7/02

Page _ of _

DATE: 6/7/02 PROJECT NO:

Comments:

Date: 6/7/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page of

Time: 11:29 AM LOCATION: PS 234 DATE: 6/7/02 PROJECT NO:

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
323	2	71.6	45.0	649	1	13	0
325	25	71.9	46.2	1141	1	10	0
310	0	71.9	45.6	917	1	11	0
324	30	72.3	46.1	1122	1	8	0
312 hallway	0	72.6	45.8	641	1	11	0
316	21	73.2	49.0	1042	1	12	0
318	23	73.7	51.6	1095	1	8	0
320	27	73.9	50.0	1045	1	8	0
322	0	74.0	49.1	581	1	7	0
NEXT TO STAIRS-113 HALLWAY	0	45.6	45.6	610	1	10	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 6/07/02

Page of

PROJECT NO:

Comments:

Date: 6/07/02