

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page of

Time: 7:00 AM LOCATION: PS 234 DATE: 6/26/02 PROJECT NO:

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	TVOCs (ppm)
OUTSIDE							
MAIN ENTRANCE	0	77.4	80.6	599	1	326	0
NEXT TO MAIN DESK	0	77.3	80.3	601	1	361	0
NORTHWEST CORNER	0	77.4	80.4	616	1	360	0
WESTSIDE	0	77.4	80.4	603	1	349	0
SOUTHWEST CORNER	0	77.4	80.6	598	1	357	0
COURTYARD	0	77.1	80.9	586	1	331	0
NORTH EAST CORNER	0	76.8	80.9	577	1	349	0
MAIN ENTRANCE	0	77.8	81.1	581	1	350	0
SOUTHEAST CORNER	0	77.9	81.1	588	1	351	0
SOUTHSIDE	0	78.1	81.2	589	1	350	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 3464	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 6/26/02

CITY_21MC100_002852266

Page of

DATE: 6/26/02 PROJECT NO:

Comments: _____

Date: 6/26/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 10

Time: 11:00
AMLOCATION: PS 234DATE: 6/26/02 PROJECT NO: _____

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
CENTRAL	6	73.6	54.1	810	1	48	0
Hall By Gym	3	74.1	55.6	803	1	49	0
Gym	2	72.1	56.1	799	1	50	0
MAIN FOYER	1	74.9	56.3	703	1	67	0
MAIN RISK	2	74.9	57.4	698	1	68	0
Hall By elevator	1	75.1	54.1	599	1	52	0
Hall By exit 1	0	74.6	54.6	560	1	36	0
Hallway 114 NEXT TO Rm	0	75.1	53.9	581	1	39	0
116	22	74.9	55.6	96	1	28	0
110	24	74.9	54.9	1391	1	24	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 6/26/02

Page of

PROJECT NO:

Comments: _____

Date: 6/26/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page of Time: 12:00 PMLOCATION: PS 234DATE: 6/26/02 PROJECT NO:

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
HALLWAY NEXT TO STAIR WELL 3	1	73.4	58.1	610	1	26	0
120	1	74.6	57.6	621	1	23	0
122	2	74.6	55.1	741	1	24	0
222	1	72.9	55.3	580	1	36	0
220	0	72.6	54.1	560	1	30	0
HALLWAY 218	0	75.5	55.8	581	1	39	0
216	0	73.6	53.6	573	1	28	0
212	1	73.1	53.1	630	1	19	0
229	0	74.7	53.8	669	1	19	0
227 HALLWAY	0	75.1	54.1	589	1	25	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 6/26/02

Page of

PROJECT NO:

Comments:

Date: 6/26/02