

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/4/02 8:00:00 PM
 ATC Group #: 7967
 Analysis Date: 6/4/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE PS 234M Project#: 14584-1823

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
01 7967 -1	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
02 7967 -2	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
03 7967 -3	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
04 7967 -4	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
05 7967 -5	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
06 7967 -6	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
07 7967 -7	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/4/02 8:00:00 PM
 ATC Group #: 7967
 Analysis Date: 6/4/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE PS 234M Project#: 14584-1823

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
08 7967 -8	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
09 7967 -9	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
10 7967 -10	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
11 7967 -11	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
12 7967 -12	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
13 7967 -13	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
14 7967 -14	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
15 7967 -15	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879