

LEAD-IN-DUST WIPE SAMPLE RESULTS

UNIT VENTILATORS

STUYVESANT HIGH SCHOOL SAMPLE LOCATION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	IS 306X SAMPLE LOCATION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)
UNIT VENTILATOR ROOM 1006 (North)	1438.6 $\mu\text{g}/\text{ft}^2$	UNIT VENTILATOR ROOM 561	528.0 $\mu\text{g}/\text{ft}^2$
UNIT VENTILATOR ROOM 938 (North)	500.6 $\mu\text{g}/\text{ft}^2$	UNIT VENTILATOR ROOM 530	143.4 $\mu\text{g}/\text{ft}^2$
UNIT VENTILATOR ROOM 911 (South)	758.9 $\mu\text{g}/\text{ft}^2$	UNIT VENTILATOR ROOM 418	149.2 $\mu\text{g}/\text{ft}^2$
UNIT VENTILATOR ROOM 826 (North)	1471.7 $\mu\text{g}/\text{ft}^2$	UNIT VENTILATOR ROOM 411	259.4 $\mu\text{g}/\text{ft}^2$
UNIT VENTILATOR ROOM 731 (South)	1494.6 $\mu\text{g}/\text{ft}^2$	UNIT VENTILATOR ROOM 322	847.2 $\mu\text{g}/\text{ft}^2$
UNIT VENTILATOR ROOM 640 (North)	538.8 $\mu\text{g}/\text{ft}^2$	UNIT VENTILATOR ROOM 360	136.2 $\mu\text{g}/\text{ft}^2$
UNIT VENTILATOR ROOM 525 (South)	1902.7 $\mu\text{g}/\text{ft}^2$	UNIT VENTILATOR ROOM 202	1556.8 $\mu\text{g}/\text{ft}^2$
UNIT VENTILATOR ROOM 451 (South)	935.7 $\mu\text{g}/\text{ft}^2$	UNIT VENTILATOR ROOM 237	1817.0 $\mu\text{g}/\text{ft}^2$
UNIT VENTILATOR ROOM 333 (South)	1746.6 $\mu\text{g}/\text{ft}^2$	UNIT VENTILATOR ROOM 115	1054.9 $\mu\text{g}/\text{ft}^2$
UNIT VENTILATOR ROOM 251 (North)	960.7 $\mu\text{g}/\text{ft}^2$	UNIT VENTILATOR ROOM 111	1571.7 $\mu\text{g}/\text{ft}^2$
STUYVESANT AVERAGE CONCENTRATION	1,174.89 $\mu\text{g}/\text{ft}^2$	IS 306X AVERAGE CONCENTRATION	806.38 $\mu\text{g}/\text{ft}^2$