

DIOXIN BULK SAMPLE RESULTS

STUYVESANT HIGH SCHOOL

UNIT VENTILATORS

DIOXIN DUST SAMPLE RESULTS 2, 3, 7, 8 TCDD EQUIVALENTS

April 27, 2002

LOCATION /SAMPLE ID	DIOXIN CONCENTRATION Nanograms per kilogram (ng/kg)	DIOXIN CONCENTRATION Parts per billion (ppb)
Room 1006 – Unit Ventilator / DX1	82	0.000082
Room 911 – Unit Ventilator / DX2	220	0.000220
Room 932 – Unit Ventilator / DX3	64	0.000064
Room 826 – Unit Ventilator / DX4	76	0.000076
Room 731 – Unit Ventilator / DX5	80	0.000080
Room 640 – Unit Ventilator / DX6	55	0.000055
Room 525 – Unit Ventilator / DX7	3,100	0.003100
Room 451 – Unit Ventilator / DX8	69	0.000069
Room 333 – Unit Ventilator / DX9	37	0.000037
Room 251 – Unit Ventilator / DX10	120	0.000120
Field Blank / DX11	0.19	0.00000019