

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306

**Attn:** Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122**Phone:** (212) 477-8941**Received:** 6/9/02

5:00:00 PM

ATC Group #: 8024**Analysis Date:** 6/9/02**Project:** H.S. Of Economics And Finance

100 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
03 8024 -1	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
04 8024 -2	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 8024 -3	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 8024 -4	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
07 8024 -5	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
08 8024 -6	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
09 8024 -7	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 6/9/02 5:00:00 PM
ATC Group #: 8024
Analysis Date: 6/9/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. Of Economics And Finance
100 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
10 8024 -8	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
11 8024 -9	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
12 8024 -10	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
13 8024 -11	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
14 8024 -12	1896.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
15 8024 -13	1912.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
16 8024 -14	1848.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
17 8024 -15	1848.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
18 8024 -16	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/9/02 5:00:00 PM
 ATC Group #: 8024
 Analysis Date: 6/9/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: H.S. Of Economics And Finance
 100 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
19 8024 -17	1864.00	0.0450	0	None Detected	0 0	0.0046	<22.24	<0.0046	

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879