

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Received: 6/11/02

9:00:00 PM

ATC Group #: 8055

Analysis Date: 6/11/02

Project: H.S. Of Economics And Finance

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 8055 -1	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
04 8055 -2	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
05 8055 -3	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
06 8055 -4	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
07 8055 -5	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
08 8055 -6	1848.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
09 8055 -7	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/11/02 9:00:00 PM
 ATC Group #: 8055
 Analysis Date: 6/11/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. Of Economics And Finance

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5μ-5	5μ		(S/mm ²)	(S/cc)	
10 8055 -8	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
11 8055 -9	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
12 8055 -10	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 8055 -11	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
14 8055 -12	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
15 8055 -13	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 8055 -14	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
17 8055 -15	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
18 8055 -16	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 6/11/02 9:00:00 PM
ATC Group #: 8055
Analysis Date: 6/11/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. Of Economics And Finance

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
19 8055 -17	1872.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879