

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Received: 6/22/02

5:30:00 PM

ATC Group #: 8229

Analysis Date: 6/23/02

Project: H.S. Of Economics And Finance

100 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5 µ	5µ		(S/mm ²)	(S/cc)	
01 8229 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
02 8229 -2	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
03 8229 -3	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
04 8229 -4	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
05 8229 -5	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
06 8229 -6	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
07 8229 -7	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 6/22/02 5:30:00 PM
ATC Group #: 8229
Analysis Date: 6/23/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. Of Economics And Finance
100 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5µ		Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)		Notes
08 8229 -8	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
09 8229 -9	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
10 8229 -10	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
11 8229 -11	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
12 8229 -12	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
13 8229 -13	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
14 8229 -14	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
15 8229 -15	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
16 8229 -16	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/22/02 5:30:00 PM
 ATC Group #: 8229
 Analysis Date: 6/23/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: H.S. Of Economics And Finance
 100 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
17 8229 -17	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24 <0.0044	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0, NY State ELAP #10879