

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4

TIME 1200

LOCATION PS150 M DATE 5/10/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside							
North		69.2	37.5	600	0	23	0.0
SE		69.4	37.2	600	0	24	0.0
East		69.7	37.6	600	0	25	0.0
NE		69.1	37.4	600	0	22	0.0
North		69.6	37.2	595	0	25	0.0
NE		69.1	37.0	596	0	23	0.0
West		69.5	37.6	590	0	25	0.0
North (avg)		69.9	37.3	595	0	24	0.0
North Entrance		70.0	37.5	590	0	25	0.0
East		70.3	37.8	580	0	23	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____ Date: 5/10/02

CITY_21MC100_002870552

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4

TIME 1:30

LOCATION P5150 M DATE 5/15/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
1st Floor		71.9	41.8	650	0	23	0.0
2nd Floor		72.0	41.6	653	0	25	0.0
3rd Floor	3	70.4	43.1	740	0	28	0.0
4th Floor	3	72.5	47.0	852	0	22	0.0
1st Floor Hall	9	72.6	45.0	850	0	25	0.0
2nd Floor	2	72.8	46.5	940	0	12	0.0
3rd Floor Hall	1	73.0	47.2	945	0	12	0.0
4th Floor	3	72.7	47.0	827	0	18	0.0
5th Floor (Hall)		73.0	45.7	820	0	20	0.0
6th Floor (Hall)		73.0	47.5	819	0	22	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/15/02

CITY_21MC100_002870553

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 1TIME 1300LOCATION PS150M DATE 5/10/02 PROJECT NO. 19125-0289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Entrance (Hall)		73.5	43.4	1040	1	22	
Reception Rm		73.2	42.3	1040	1	23	
Nurse Rm	2	72.6	42.4	1000	1	24	
Kitchen		70.5	41.0	1070	1	21	
Hall of Dept 2		70.7	41.2	1130		2	
Nurse Rm	24	73.4	38.4	1800	1	26	
Hall	23	75.0	46.4	1160	1	20	
Hall (Hall)		74.2	44.0	1070	1	27	
Hall	20	74.5	43.4	1011	1	20	
Eng Rm (Hall)		74.9	40.2	800	1	26	
Guideline levels ASHRAE/AHIA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: [Signature] Date: 5/10/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4TIME 1:33LOCATION PS150M DATE 5/10/02 PROJECT NO. 19125-0289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Lab. Room (main)		75.0	39.3	810	1	25	0.1
Lab. Room (main)		75.1	39.0	708	1	25	0.1
402		72.1	40.4	736	1	25	0.1
401	33	74.3	43.0	1074	1	25	0.1
Lab. Room (main)		72.5	40.0	722	1	25	0.1
501		70.2	45.2	622	1	30	0.1
502		73.4	42.5	1035	1	25	0.1
Lab. Room (main)		72.0	42.0	810	1	25	0.1
503	21	74.2	45.0	722	1	25	0.1
504	3	74.3	48.5	700	1	25	0.1
Guideline levels ASHRAE/AHHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5-10-02