

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 1 of 1

Time: 1:10 PM

LOCATION: PS ISC

DATE: 5/31/02

PROJECT NO: 11125-0287

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
MAIN REJCT	1	79.6	47.4	659	1	22	C
MAIN RESE	3	79.5	47.6	666	1	19	C
NEXT TO WEST STAIRS HALL	0	79.6	46.8	726	1	18	C
MAIN LOBBY	4	79.3	46.8	715	1	18	C
LOBBY REJCT	1	79.1	45.1	760	1	18	C
MAIN OFFICE	3	79.8	46.6	704	1	19	C
ENTRANCE REJCT	1	76.2	43.4	654	1	16	C
NEXT TO BOYS REJCT HALL	0	76.2	46.6	664	1	15	C
NEXT TO GIRLS REJCT HALL	0	77.2	47.6	716	1	11	C
NEXT TO EAST STAIRS HALL	0	77.9	47.3	696	1	12	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5/31/02

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 2 of 2

Time: 4:40 pm LOCATION: PS 150

DATE: 3/31/02 PROJECT NO: 17422-0005

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
RECEPTION ROOM	0	13.1	46.7	677	1	12	C
N. BOYS REST ROOM	1	74.1	46.7	703	1	11	C
KITCHEN	2	72.3	46.3	710	1	5	C
MEN'S REST ROOM	1	72.0	47.1	651	1	10	C
NEXT TO STAIRS	1	73.0	45.1	703	1	10	C
404	25	73.9	45.8	1109	1	5	C
403	18	73.7	46.1	871	1	7	C
403 HALLWAY	3	73.1	46.3	741	1	10	C
NEXT TO BOYS REST ROOM	0	73.1	46.1	702	1	10	C
NEXT TO GIRLS REST ROOM	1	73.2	45.5	597	1	10	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 3/31/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page ³ of 4

Time: 2:00 pm LOCATION: PS 150 DATE: 5/31/02 PROJECT NO: 19125-C201

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
HALLWAY NEXT TO STAIR Rm	C	78.1	40.3	1093	1	16	C
402	C	77.5	45.0	765	1	10	C
401	25	71.5	45.2	567	1	10	C
HALL BY WEST STAIRS	C	77.6	40.6	1041	1	16	C
501	25	76.1	42.1	977	1	17	C
502	20	76.1	41.2	1096	1	11	C
503	21	75.2	35.3	1007	1	9	C
504	25	75.4	38.3	1055	1	15	C
504 HALLWAY	C	77.9	41.1	1043	1	15	C
HALL BY EAST STAIRS	C	78.2	39.4	1026	1	14	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/31/02

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4

Time: 2:25 pm LOCATION: P-150 DATE: 5/31/02 PROJECT NO: MHS-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
OUTSIDE							
SOUTH SIDE	10	85.7	54.0	507	1	25	C
SOUT EAST CORNER	5	85.7	52.0	541	1	25	C
EAST SIDE	6	85.7	52.0	546	1	25	C
NORTHEAST CORNER	6	85.7	52.0	546	1	24	C
EAST TOP OF STAIRS	6	85.7	52.0	543	1	26	C
NORTHWEST CORNER	6	85.7	52.0	541	1	26	C
WEST SIDE	1	85.7	52.0	547	1	24	C
MAIN ENTRANCE	2	80.1	52.0	541	1	22	C
WENT TO TOP OF STAIRS	6	80.1	52.0	561	1	24	C
NORTH SIDE	6	80.1	52.1	601	1	24	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5/31/02