

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4

Time: 1:05 pm LOCATION: PS 150 DATE: 6/14/02 PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (ug/m ³)	TVOCs (ppm)
<u>OUTSIDE</u>							
<u>SOUTHSIDE</u>	<u>0</u>	<u>67.8</u>	<u>66.8</u>	<u>541</u>	<u>1</u>	<u>21</u>	<u>0</u>
<u>SOUTH EAST CORNER</u>	<u>1</u>	<u>67.8</u>	<u>66.8</u>	<u>546</u>	<u>1</u>	<u>25</u>	<u>0</u>
<u>EASTSIDE</u>	<u>2</u>	<u>67.8</u>	<u>66.9</u>	<u>559</u>	<u>1</u>	<u>24</u>	<u>0</u>
<u>NORTHEAST CORNER</u>	<u>0</u>	<u>67.8</u>	<u>66.9</u>	<u>569</u>	<u>1</u>	<u>21</u>	<u>0</u>
<u>EAST TOP OF STAIRS</u>	<u>0</u>	<u>67.8</u>	<u>66.9</u>	<u>573</u>	<u>1</u>	<u>19</u>	<u>0</u>
<u>NORTHWEST CORNER</u>	<u>0</u>	<u>67.8</u>	<u>66.9</u>	<u>581</u>	<u>1</u>	<u>24</u>	<u>0</u>
<u>WESTSIDE</u>	<u>0</u>	<u>67.8</u>	<u>66.9</u>	<u>555</u>	<u>1</u>	<u>29</u>	<u>0</u>
<u>MAIN ENTRANCE</u>	<u>0</u>	<u>67.8</u>	<u>66.9</u>	<u>523</u>	<u>1</u>	<u>26</u>	<u>0</u>
<u>NEXT TO TOP OF STAIRS</u>	<u>0</u>	<u>67.8</u>	<u>66.9</u>	<u>591</u>	<u>1</u>	<u>26</u>	<u>0</u>
<u>NORTHSIDE</u>	<u>0</u>	<u>67.8</u>	<u>66.9</u>	<u>599</u>	<u>1</u>	<u>21</u>	<u>0</u>
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Kim Zlatos Date: 6/14/02

CITY_21MC100_002870768

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4

Time: 1:31 PM

LOCATION:

PS 150

DATE: 6/14/02

PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (ug/m ³)	TVOCs (ppm)
MAIN FOYER	2	72.1	56.6	610	1	21	0
MAIN RESE	2	72.3	56.6	629	1	19	0
NEXT TO WEST STAIRS	1	72.6	56.6	591	1	16	0
MAIN LOBBY	4	72.4	56.6	646	1	15	0
EDS ROOM	1	73.6	55.1	604	1	14	0
MAIN OFFICE	3	72.9	55.3	629	1	16	0
GUIDANCE RM	1	73.3	55.3	583	1	11	0
NEXT TO BOYS RM	0	72.5	55.1	571	1	12	0
NEXT TO GIRLS RM	0	72.5	55.1	566	1	13	0
NEXT TO EAST STAIRS HALLWAY	0	72.9	55.3	589	1	13	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: *John J. Banta*

Date: 6/14/02

**ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT**

Page 3 of 4

Time: 1:50 pm

LOCATION: PS 150

DATE: 6/14/02

PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (ug/m ³)	TVOCs (ppm)
Resource Room	3	73.1	55.6	641	1	16	0
Nurse Room	1	73.6	55.9	601	1	11	0
Kitchen	2	73.6	55.6	626	1	15	0
Music Room	2	73.9	56.1	621	1	15	0
NEXT TO SLOP SINK	0	72.1	56.1	589	1	10	0
404	25	73.6	56.2	1126	1	11	0
403 HALLWAY	0	72.9	56.2	588	1	13	0
403 CLASS ROOM	25	73.1	56.2	1131	1	16	0
NEXT TO BOYS ROOM	1	72.6	56.2	603	1	17	0
NEXT TO GIRLS ROOM	0	72.6	56.2	599	1	12	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/14/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4Time: 2:10 pmLOCATION: PS 150DATE: 6/14/02PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (ug/m ³)	TVOCs (ppm)
NEXT TO STAFF RM HALLWAY	0	72.1	55.1	577	1	18	0
402	24	73.6	55.3	1143	1	16	0
401	22	73.9	55.4	1124	1	17	0
HALL NEXT TO WEST STAIRS	1	72.2	55.6	601	1	18	0
501	25	73.4	55.6	1156	1	18	0
502	26	73.9	55.1	1143	1	13	0
503	21	74.1	55.3	1026	1	16	0
504	22	72.9	55.1	1049	1	10	0
504 HALLWAY	1	72.6	55.1	601	1	12	0
HALL BY EAST STAIRS	0	72.3	55.9	581	1	14	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Date: 6/14/02