

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/9/02 5:30:00 PM
 ATC Group #: 8025
 Analysis Date: 6/9/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE PS 234M Project#: 14584-1823

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8025 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
02 8025 -2	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
03 8025 -3	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
04 8025 -4	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
05 8025 -5	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
06 8025 -6	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
07 8025 -7	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 6/9/02 5:30:00 PM
ATC Group #: 8025
Analysis Date: 6/9/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE PS 234M Project#: 14584-1823

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
08 8025 -8	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
09 8025 -9	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
10 8025 -10	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
11 8025 -11	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
12 8025 -12	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
13 8025 -13	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
14 8025 -14	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
15 8025 -15	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879