

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 6/21/02
ATC Group #: 8212
Analysis Date: 6/22/02

10:00:00 PM

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE PS 234M Project#: 14584-1823

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)
01 8212 -1	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24 <0.0044
02 8212 -2	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24 <0.0044
03 8212 -3	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24 <0.0044
04 8212 -4	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24 <0.0044
05 8212 -5	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24 <0.0045
06 8212 -6	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24 <0.0044
07 8212 -7	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24 <0.0044

MARK PEYSAKHOV

Analyzed by:

MICHAEL

A. GORYCKI, Ph.D.

Approved:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Confidence limits and laboratory and analysis accuracy and precision is available upon request.

personnel. This lab is only responsible for data reported in structures/mm². This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Confidence limits and laboratory and analysis accuracy and precision is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 6/21/02 4:00:00 PM
ATC Group #: 8212
Analysis Date: 6/22/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE PS 234M Project#: 14584-1823

**Asbestos Fiber Analysis by Transmission Electron Microscopy
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
					0.5µ-5	5µ		(S/mm ²)	(S/cc)
08 8212 -8	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
09 8212 -9	1912.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
10 8212 -10	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
11 8212 -11	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
12 8212 -12	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
13 8212 -13	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
14 8212 -14	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
15 8212 -15	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045


MARK PEYSAKHOV

Analyzed by:



MICHAEL V. GORYCKI, Ph.D.

Appl:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported. Labels, confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

sonnel. This lab is only responsible for data reported in structures/mm². This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported. Labels, confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLMTEM #101187-0, NY State ELAP #10879