

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4TIME 1200LOCATION PS150 MDATE 2/1/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Entrance		44.8	51.1	460	0	43	0
North Side		44.9	51.3	471	0	40	0
South Side		44.8	51.4	499	0	40	0
East Side		44.7	52.0	503	0	42	0
West Side		44.6	52.5	490	0	45	0
NW Corner		44.7	53.1	493	0	41	0
NE Corner		44.9	52.9	509	0	40	0
SW Corner		45.3	52.7	517	0	38	0
SE Corner		44.1	52.6	529	0	39	0
(By School) Top of Stairs		44.6	51.9	479	0	41	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: J. Chy Date: 2/1/02

CITY_21MC100_002853416

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4TIME 1230LOCATION PS150 MDATE 2/1/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
By Main Desk	10	71.0	49.5	760	0	37	0
Main Lobby Area	9	71.1	49.1	769	0	39	0
Clubs by Main Desk	—	72.2	47.3	804	0	28	0
Foyer Area		73.0	45.6	656	1	40	0
General Office	5	73.4	44.0	664	1	41	0
Principal office	—	74.1	43.7	687	1	38	0
Guidance Room	5	73.9	42.5	822	1	49	0
Hall by bathrooms	—	74.6	40.2	656	1	38	0
Resource Room	4	75.6	40.1	736	1	42	0
Kitchen Area	4	76.3	39.2	802	1	40	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jin Chen Date: 2/1/02

CITY_21MC100_002853417

ATC ASSOCIATES, INC.

Page 3 of 4

INDOOR AIR QUALITY FIELD REPORT

TIME 1300LOCATION PS150 MDATE 2/1/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Nurse Room		72.1	38.2	849	1	49	0
1st Fl. Hall by Slop Sink		72.0	37.5	838	1	42	0
East Stairs Room		76.0	36.0	597	1	49	0
404		74.0	31.2	573	1	30	0
2nd Fl. Hall by Slop Sink		74.0	31.4	840	1	38	0
403		74.6	32.9	820	1	38	0
Hall by East Stair		75.0	34.2	705	1	50	0
Hall by Girl Rm		75.3	34.5	711	1	51	0
402		75.6	34.2	699	1	29	0
401		76.2	38.9	697	1	29	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Ji Cai Date: 2/1/02

CITY_21MC100_002853418

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4TIME 1330LOCATION PS150 MDATE 2/1/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall by West stairs		76.0	32.7	626	1	43	0
West Stairs		76.1	32.2	683	1	49	0
501		75.0	32.8	687	1	42	0
502		74.3	32.9	640	1	44	0
Hall by Teacher Rm		74.2	33.0	697	1	47	0
Hall by Boys Rm		74.1	33.6	680	1	49	0
Hall by Girls Rm		74.2	32.8	683	1	50	0
503		73.9	33.8	615	1	38	0
504		73.5	34.2	621	1	35	0
503 (Hall)		73.9	33.7	619	1	49	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jay Ch Date: 2/1/02