

ATC ASSOCIATES, INC.

Page 1 of 4TIME 830

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS150 MDATE 02.02.02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Lobby		71.5	22.3	571	0	7	0
Room #2		71.4	18.3	470	0	4	0
Room #3		70.5	17.7	580	0	25	0
Resource Room		71.8	18.2	555	0	4	0
Nurse Room		72.6	17.0	511	0	6	0
Kitchen		73.1	18.1	490	0	10	0
Multi-purpose Rm		74.1	20.1	475	0	11	0
Room 404		73.5	17.2	444	0	8	0
Room 403		72.6	16.3	444	0	5	0
Room 402		72.3	15.5	433	0	8	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Tim Angelis / 402/14 Date: 02.02.02

CITY_21MC100_002853425

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4TIME 910LOCATION PS150 MDATE 02.02.02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Room 401		72.0	15.3	438	0	5	0
Room 501		70.6	15.5	440	0	8	0
Room 502		69.8	14.9	446	0	10	0
Room 503		69.7	16.8	516	0	18	0
Room 504		69.2	19.2	460	0	33	0
Entrance 1FL		73.8	18.0	500	0	6	0
Outside Eastside		45.5	13.7	430	1	4	0
Outside Southside		40.2	13.4	423	0	4	0
outside West side		41.7	17.9	430	0	6	0
outside Northside		37.5	18.3	424	1	4	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.Signature: Tom AmstislavskyDate: 02.02.02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4TIME 1130LOCATION PS150 M DATE 02.02.02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Lobby		71.4	17.3	630	0	5	0
Room #2		72.0	19.0	474	0	4	0
Room #3		70.1	18.2	563	0	6	0
Resource Room		72.1	18.3	549	0	5	0
Nurse Room		72.0	16.9	503	0	4	0
Multi Purpose Room		73.8	20.3	492	0	110	0
Kitchen		73.7	17.9	483	0	8	0
Room #404		73.1	17.6	434	0	5	0
Room #403		73.0	16.2	500	0	7	0
Room #402		72.0	15.1	445	0	9	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Tim Anastasiadis Date: 02.02.02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1210LOCATION PS150 MDATE 02.02.02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Room #401		71.8	15.0	440	0	5	0
Room #501		69.8	14.6	442	0	6	0
Room #502		69.6	14.3	450	0	10	0
Room #503		69.1	15.9	521	0	19	0
Room #504		69.8	20.0	457	0	29	0
Entrance 1FL		74.0	18.2	503	0	6	0
outside East side		42.0	18.6	444	0	5	0
outside South side		49.2	18.7	478	0	5	0
outside West side		39.9	19.6	426	0	6	0
outside North side		38.9	20.2	425	1	5	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Tim Anastis/owner Date: 02.02.02