


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4TIME 1400LOCATION PS150 MDATE 3/6/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
South Side Outside		43.3	30.0	481	0	28	0
SE Corner Outside		43.0	29.8	485	0	30	0
East Side Outside		43.3	29.1	491	0	26	0
NE Corner Outside		43.8	28.8	496	0	20	0
North Side Outside		43.1	30.0	490	0	18	0
NW Corner Outside		42.8	30.6	486	0	20	0
West Outside		42.5	31.3	499	0	23	0
Top stairs. North Outside		43.1	31.8	496	0	20	0
Top stairs East Side Outside		43.3	32.6	500	0	19	0
Main Entrance Outside		43.3	32.3	510	0	20	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/6/02

CITY_21MC100_002853529

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4TIME 1430LOCATION PS150 M DATE 3/6/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Foyer	-	68.9	29.1	690	0	18	0
Hall by West Stairs	-	68.7	28.8	699	0	16	0
Main Desk		70.0	29.3	709	0	15	0
Ed's Room	5	72.3	30.1	801	0	10	0
Main Lobby Area	-	70.3	29.6	719	0	12	0
Main Office	3	71.8	31.1	807	0	13	0
Prin. Office	-	72.0	31.5	781	0	14	0
Guidance Rm.		71.6	30.8	751	0	16	0
Hall by boys Rm.		73.0	31.3	740	0	18	0
Hall by Girls Rm.		73.2	31.5	743	0	18	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jin Chen Date: 3/6/02


CITY_21MC100_002853530

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1500LOCATION PS150 MDATE 3/6/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall by Slop. Sink.		73.9	29.6	709	0	18	0
Resource Rm.		72.8	27.1	800	0	15	0
Nurse Rm		73.0	28.3	719	0	16	0
Kitchen Area		72.6	28.6	809	0	15	0
Music Rm		71.8	30.1	759	0	14	0
Hall by East Stairs.		74.0	29.0	601	0	17	0
East Stairs		73.6	28.6	596	0	16	0
404		72.6	29.1	700	0	13	0
404 (Hall)		73.9	28.0	715	0	18	0
403		73.3	28.8	696	0	14	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/6/02

CITY_21MC100_002853531


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4TIME 1535LOCATION PS150 MDATE 3/6/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Hall by Girls Rm		74.0	28.0	709	0	18	0
Hall by Boys Rm		73.8	28.1	711	0	17	0
Hall by Teachers Rm		73.9	28.4	715	0	18	0
402		72.8	26.9	699	0	16	0
401		72.6	26.6	715	0	15	0
501		73.0	25.0	729	0	16	0
Hall by West Stairs		74.1	28.3	709	0	19	0
502		73.8	25.1	801	0	12	0
503		73.6	26.3	711	0	13	0
504		74.0	24.3	715	0	16	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/6/02

CITY_21MC100_002853532