

**ATC Associates**

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



**Attn:** Mr. Bernard Orlan  
N.Y.C. Board of Education  
28-11 Queens Plaza North  
Long Island City, NY 11101

**Received:** 3/5/02 8:15:00 PM  
**ATC Group #:** 6941  
**Analysis Date:** 3/5/02

**Fax:** (212) 475-4122 **Phone:** (212) 477-8941

**Project:** NYC-BOE PS 150M Project#: 14584-0824

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed  
by EPA 40 CFR Part 763 Final Rule (AHERA)**

| Sample        | Volume  | Area<br>Analyzed | Non<br>Asb | Asbestos<br>Type(s) | # Structures |    | Analytical<br>Sensitivity<br>(S/cc) | Asbestos<br>Concentration |         | Notes |
|---------------|---------|------------------|------------|---------------------|--------------|----|-------------------------------------|---------------------------|---------|-------|
|               |         |                  |            |                     | 0.5µ-5<br>µ  | 5µ |                                     | (S/mm <sup>2</sup> )      | (S/cc)  |       |
| 01<br>6941 -1 | 1920.00 | 0.0450           | 0          | None Detected       | 0            | 0  | 0.0045                              | <22.24                    | <0.0045 |       |
| 02<br>6941 -2 | 1920.00 | 0.0450           | 0          | None Detected       | 0            | 0  | 0.0045                              | <22.24                    | <0.0045 |       |
| 03<br>6941 -3 | 1920.00 | 0.0450           | 0          | None Detected       | 0            | 0  | 0.0045                              | <22.24                    | <0.0045 |       |
| 04<br>6941 -4 | 1920.00 | 0.0450           | 0          | None Detected       | 0            | 0  | 0.0045                              | <22.24                    | <0.0045 |       |
| 05<br>6941 -5 | 1920.00 | 0.0450           | 0          | None Detected       | 0            | 0  | 0.0045                              | <22.24                    | <0.0045 |       |
| 06<br>6941 -6 | 1920.00 | 0.0450           | 0          | None Detected       | 0            | 0  | 0.0045                              | <22.24                    | <0.0045 |       |
| 07<br>6941 -7 | 1912.00 | 0.0450           | 0          | None Detected       | 0            | 0  | 0.0045                              | <22.24                    | <0.0045 |       |

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in street address, which is dependent on volume collected by the laboratory personnel. This lab is only responsible for data reported in structures/mm<sup>2</sup>. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported herein. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10670

CITY\_21MC100\_002853943













