

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 2/11/02 9:00:00 PM

ATC Group #: 6648

Analysis Date: 2/12/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC BOE H.S. For Leadership & Public Services
90 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5µ	5µ		(S/mm²)	(S/cc)	
04 6648 -1	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 6648 -2	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 6648 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
07 6648 -4	1816.00	0.0450	0	CHRYSTOLE	0	1	0.0047	22.24	0.0047	
08 6648 -5	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
09 6648 -6	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
10 6648 -7	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
11 6648 -8	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by: 

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002872192

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 2/11/02 9:00:00 PM

ATC Group #: 6648

Analysis Date: 2/12/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC BOE H.S. For Leadership & Public Services
90 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
12 6648 -9	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
13 6648 -10	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
14 6648 -11	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
15 6648 -12	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
16 6648 -13	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
17 6648 -14	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
18 6648 -15	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
19 6648 -16	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
20 6648 -17	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
21 6648 -18	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002872193