NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1816
Lab Group #:	6648	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	4	**Grid Opening Size:**	0.01124
Client Sample #:	07	**Area Examined:**	0.04496 mm²
GRID BOX:	814	**Magnification:**	20,000
GRID ID:	5N10	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	2/12/02

Analysis Performed By: RP
ROMAN PEYSAKHOV

GO.		Structure	Structure Type				Length		ID of Structure . N or √				EDS
No	Coord	No	F	B	C	M	>=05 µ <5µ	>=5µ	Chrys	Amphibole	Nonasb	Ambig/ND	(Nonadb Elements)
5N 1	I3	1		√				√	√				
2	Q3	NSD											
3	J2	11											
4	I4	4											
10													

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					