

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306

**Attn:** Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122**Phone:** (212) 477-8941**Project:** H.S. for Leadership & Public Service

90 Trinity Place, New York, NY

Received: 6/1/02

5:00:00 PM

ATC Group #: 7932**Analysis Date:** 6/1/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
04 7932 -1	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 7932 -2	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 7932 -3	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
07 7932 -4	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
08 7932 -5	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
09 7932 -6	1848.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
10 7932 -7	1864.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/1/02 5:00:00 PM
 ATC Group #: 7932
 Analysis Date: 6/1/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: H.S. for Leadership & Public Service
 90 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
11 7932 -8	1864.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
12 7932 -9	1864.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
13 7932 -10	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
14 7932 -11	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
15 7932 -12	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
16 7932 -13	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
17 7932 -14	1864.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
18 7932 -15	1872.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
19 7932 -16	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 6/1/02 5:00:00 PM
ATC Group #: 7932
Analysis Date: 6/1/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. for Leadership & Public Service
90 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
20 7932 -17	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
21 7932 -18	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879