

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Project: H.S. for Leadership & Public Service

90 Trinity Place, New York, NY

Received: 6/3/02

9:00:00 PM

ATC Group #: 7952

Analysis Date: 6/4/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
04 7952 -1	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
05 7952 -2	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
06 7952 -3	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
07 7952 -4	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
08 7952 -5	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
09 7952 -6	1921.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
10 7952 -7	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/3/02 9:00:00 PM
 ATC Group #: 7952
 Analysis Date: 6/4/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: H.S. for Leadership & Public Service
 90 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5 μ -5 5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
11 7952 -8	1814.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
12 7952 -9	1808.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
13 7952 -10	1816.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
14 7952 -11	1800.00	0.0450	0	None Detected	0	0	0.0048 <22.24 <0.0048	
15 7952 -12	1824.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
16 7952 -13	1832.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
17 7952 -14	1832.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
18 7952 -15	1840.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
19 7952 -16	1856.00	0.0450	0	None Detected	0	0	0.0046 <22.24 <0.0046	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/3/02 9:00:00 PM
 ATC Group #: 7952
 Analysis Date: 6/4/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: H.S. for Leadership & Public Service
 90 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
20 7952 -17	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
21 7952 -18	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879