

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/25/02 9:00:00 PM
 ATC Group #: 8280
 Analysis Date: 6/25/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. for Leadership & Public Service

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
04 8280 -1	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
05 8280 -2	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
06 8280 -3	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
07 8280 -4	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
08 8280 -5	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
09 8280 -6	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
10 8280 -7	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 6/25/02 9:00:00 PM
ATC Group #: 8280
Analysis Date: 6/25/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. for Leadership & Public Service

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
11 8280 -8	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
12 8280 -9	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
13 8280 -10	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
14 8280 -11	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
15 8280 -12	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
16 8280 -13	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
17 8280 -14	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
18 8280 -15	1864.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
19 8280 -16	1864.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/25/02 9:00:00 PM
 ATC Group #: 8280
 Analysis Date: 6/25/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. for Leadership & Public Service

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
20 8280 -17	1864.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
21 8280 -18	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879