

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6TIME 1200LOCATION PS 234 M DATE 3/11/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
755 Outside Main Entrance		33.1	15.9	360	0	22	0
7:55 Inside By Main Desk		70.3	14.5	503	0	16	0
SW Corner Outside		33.9	14.0	363	0	20	0
West Side Outside		34.2	14.3	370	0	19	0
NW Corner Outside		34.6	14.9	368	0	22	0
North Side Outside		35.0	15.6	375	0	23	0
NE Corner Outside		35.8	16.0	380	0	25	0
SE Corner Outside		35.3	16.6	389	0	23	0
Courtyard Outside		34.8	16.9	399	0	22	0
Main Entrance Outside		35.1	17.3	406	0	20	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____


The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 3/11/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 6TIME 1225LOCATION PS 234 M DATE 3/11/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Foyer		71.6	14.8	580	0	12	0
Main Desk	4	70.7	14.4	557	0	11	0
Hall by Gym.	—	70.9	14.5	550	0	11	0
Gym	23	71.1	14.5	584	0	10	0
Cafeteria		71.9	15.1	558	0	8	0
Hall by Elevator	—	68.4	13.7	532	0	13	0
Hall by Exit 1	—	68.0	13.4	546	0	12	0
114 (Hall)	—	66.9	14.1	695	0	12	0
116	15	67.6	16.1	763	0	10	0
118	20	67.4	15.8	754	0	15	0
Guideline levels ASHRAE/AHIA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/11/02


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6TIME 1245LOCATION PS 234 M DATE 3/11/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
120	24	68.1	16.9	817	0	18	0
122	23	68.4	15.8	679	0	15	0
Hall by Stair-3	-	68.1	16.0	685	0	14	0
Stair-3	-	67.5	16.2	640	0	14	0
222	23	71.1	16.3	669	0	9	0
220	2	71.2	16.0	636	0	10	0
220 (Hall)	-	69.5	16.5	645	0	11	0
218	24	71.8	15.6	674	0	10	0
216	20	71.3	15.4	655	0	10	0
214 (Hall)		71.3	15.7	628	0	10	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ng/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/11/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 6TIME 1300LOCATION PS 234 MDATE 3/11/02PROJECT NO. 19125 - 279

Location	Occup	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
229 (Hall)	—	71.3	15.3	635	0	9	0
227 (Hall)	—	71.0	15.0	637	0	9	0
225	23	71.4	15.3	655	0	12	0
223	25	73.3	17.6	869	0	8	0
210 (Hall)	—	71.4	15.2	676	0	9	0
Hall by stair 1	—	71.3	15.1	670	0	10	0
219	A—	73.4	15.6	668	0	11	0
206 (Hall)	—	73.3	14.8	685	0	10	0
206 (Hall)	—	73.2	14.9	680	0	8	0
215	31	74.3	15.0	761	0	9	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____


Date: 3/11/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6TIME 1320LOCATION PS 234 MDATE 3/11/02PROJECT NO. 19125-279

Location	Occup.	Temperature (F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
211	26	73.7	15.3	800	0	9	0
201	3	72.2	13.6	620	0	9	0
202 (Hall)	-	72.0	13.5	614	0	8	0
301	5	71.1	14.4	654	0	9	0
302 (Hall)	-	71.4	14.6	639	0	10	0
305	1	71.1	14.0	627	0	9	0
304	26	72.6	16.1	807	0	11	0
311	20	72.5	15.3	731	0	9	0
306	-	71.8	15.0	720	0	10	0
315	6	71.4	13.7	626	0	9	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____


The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/11/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6TIME 1345LOCATION PS 234 M DATE 3/11/02 PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
308	18	70.9	14.7	723	0	11	0
319	18	70.8	15.3	782	0	9	0
323	21	71.6	14.5	702	0	9	0
310	2	71.6	14.6	749	0	9	0
325	2	71.8	15.9	809	0	11	0
329	26	72.1	15.4	802	0	10	0
316	25	74.3	14.6	719	0	10	0
318	-	75.4	13.6	661	0	10	0
320	23	74.1	13.8	689	0	12	0
322	24	73.2	14.2	684	0	10	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/11/02