

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT


Page 1 of 6TIME 1200LOCATION PS 234 MDATE 3/20/02PROJECT NO. 19125-279

Location	Occupancy	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
0750 Main Entrance		43.6	48.3	403	0	20	0
0750 Inside Main Desk		68.9	36.8	520	0	12	0
SW Corner		47.6	46.0	400	0	16	0
West Side		47.0	46.5	345	0	18	0
BNW Corner		46.8	46.9	409	0	14	0
North Side		46.1	47.3	416	0	14	0
Courtyard		45.9	47.7	422	0	13	0
NE Corner		45.6	48.1	429	0	16	0
Main Entrance		45.0	48.4	435	0	16	0
SE Corner		44.7	48.9	439	0	15	0
Guideline levels ASHRAE/AHIA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 3/20/02


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 6TIME 1230LOCATION PS 234 M DATE 3/20/02 PROJECT NO. 19125-279

Location	Occup	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (ug/m ³)	TVOCs (ppm)
301	3	74.9	26.7	870	0	8	0
301 (hall)		75.2	28.4	990	0	10	0
302		74.6	27.0	779	0	8	0
304	21	75.6	29.1	1205	0	12	0
306		74.0	28.5	915	0	9	0
305	20	74.1	28.8	1009	0	11	0
311		74.7	29.2	930	0	12	0
315	35	73.6	28.6	825	0	11	0
308	21	73.3	29.1	1060	0	13	0
319	17	72.5	29.4	844	0	8	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/20/02

CITY_21MC100_002877743

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6TIME 1255LOCATION PS 234 MDATE 3/20/02PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
323	22	72.2	30.2	815	0	8	0
310	3	71.8	30.1	766	0	7	0
325	25	71.8	31.9	856	0	9	0
329	1	71.9	31.0	730	0	9	0
316	20	73.7	31.7	764	0	7	0
318	3	75.3	30.9	656	0	7	0
320	26	75.0	30.6	702	0	7	0
322	21	74.7	30.6	708	0	8	0
Hall by Stair 3	-	74.5	30.3	697	0	8	0
222	27	73.6	31.0	786	0	11	0
Guideline levels ASHRAE/AHHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/20/02

CITY_21MC100_002877744

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 6TIME 1315LOCATION PS 234 MDATE 3/20/02PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
220	30	75.2	30.9	752	0	8	0
218	25	76.4	30.7	702	0	8	0
216	17	75.6	30.8	733	0	8	0
229	25	73.9	30.1	862	0	9	0
225	24	74.1	31.8	980	0	16	0
210	—	74.3	31.3	823	0	8	0
Hall by Stair 1	—	73.8	30.3	810	0	8	0
223	20	75.3	31.6	828	0	8	0
219 (4th)	—	75.5	31.0	920	0	10	0
206	20	75.3	30.4	845	0	14	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 3/20/02


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6TIME 1340LOCATION PS 234 MDATE 3/20/02PROJECT NO. 19125-279

Location	Occup	Temperature (F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
206 (hall)		75.5	31.3	1030	0	16	0
215 (hall)		75.5	31.9	1100	0	15	0
211	29	75.2	31.4	1080	0	9	0
202		75.3	31.9	1009	0	10	0
201		75.4	31.6	1016	0	12	0
201 (hall)		75.5	31.2	1015	0	12	0
118	24	71.4	32.2	842	0	14	0
120	23	71.6	33.9	869	0	13	0
122	22	71.0	32.6	767	0	18	0
116		71.9	32.0	755	0	11	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/20/02


CITY_21MC100_002877746

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6TIME 1410LOCATION PS 234 M DATE 3/20/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Foyer		68.3	30.0	728	0	21	0
Main Desk		68.0	29.2	762	0	20	0
Hall by Gym		70.4	30.0	785	0	16	0
Gym		71.0	30.3	709	0	18	0
Cafeteria		73.6	28.9	769	0	14	0
Hall by Elevator		72.2	31.0	627	0	16	0
Hall by Stair 1		71.5	31.9	600	0	17	0
Hall by South Exit		71.0	32.1	580	0	16	0
Hall by Exit 1		71.5	31.6	590	0	17	0
114 (Hrm.)		71.1	31.7	730	0	10	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/20/02

CITY_21MC100_002877747