


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 2TIME 1200LOCATION PS 234 M DATE 3/27/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
<u>Outside</u>							
<u>740 Main Entrance</u> <u>NEW Elevator</u>		<u>50.3</u>	<u>38.6</u>	<u>409</u>	<u>0</u>	<u>26</u>	<u>0</u>
<u>740 Inside Main Entrance</u>		<u>69.9</u>	<u>31.0</u>	<u>519</u>	<u>0</u>	<u>19</u>	<u>0</u>
<u>SW Corner</u>		<u>54.6</u>	<u>34.0</u>	<u>434</u>	<u>0</u>	<u>10</u>	<u>0</u>
<u>West Side</u>		<u>54.0</u>	<u>34.2</u>	<u>439</u>	<u>0</u>	<u>11</u>	<u>0</u>
<u>NW Corner</u>		<u>53.8</u>	<u>34.6</u>	<u>436</u>	<u>0</u>	<u>12</u>	<u>0</u>
<u>Playground</u>		<u>53.5</u>	<u>34.9</u>	<u>440</u>	<u>0</u>	<u>9</u>	<u>0</u>
<u>Courtyard</u>		<u>53.0</u>	<u>35.3</u>	<u>446</u>	<u>0</u>	<u>12</u>	<u>0</u>
<u>NE Corner</u>		<u>52.8</u>	<u>35.8</u>	<u>437</u>	<u>0</u>	<u>11</u>	<u>0</u>
<u>Main Entrance</u>		<u>53.1</u>	<u>36.1</u>	<u>435</u>	<u>0</u>	<u>10</u>	<u>0</u>
<u>SE Corner</u>		<u>53.6</u>	<u>36.3</u>	<u>434</u>	<u>0</u>	<u>12</u>	<u>0</u>
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/27/02

ATC ASSOCIATES, INC.

Page 2 of 6

INDOOR AIR QUALITY FIELD REPORT


TIME 1220LOCATION PS 234 MDATE 3/27/02PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Foyer		67.0	39.0	560	0	10	0
Main Desk		67.3	38.9	566	0	9	0
Hall by Cafeteria		69.9	39.0	620	0	9	0
Gym	Full	68.4	39.6	673	0	18	0
Cafeteria		72.9	36.7	595	0	10	0
Hall by Elevator		72.9	34.9	587	0	11	0
Hall by Exit 1		74.2	34.6	611	0	13	0
114 (Hall)		73.8	33.8	620	0	14	0
116	13	74.3	37.3	742	0	11	0
118	18	74.6	36.6	832	0	10	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____



Date: _____

3/27/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6TIME 1245LOCATION PS 234 M DATE 3/27/02 PROJECT NO. 19125 - 279

Location	Occup	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
120	20	74.3	35.6	848	0	14	0
122	16	73.3	33.8	625	0	12	0
Hall by Stair 3	-	73.2	33.3	630	0	12	0
222	-	73.0	31.6	615	0	8	0
220	23	75.9	32.0	691	0	9	0
220 (Hall)		76.6	30.5	651	0	9	0
218 (Hall)		76.6	30.5	649	0	9	0
216 (Hall)		76.7	30.5	723	0	8	0
229 (Hall)		77.4	29.6	650	0	10	0
227 (Hall)		77.6	29.5	658	0	9	0
Guideline levels ASHRAE/AHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 3/27/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 6


TIME 1315

LOCATION PS 234 M DATE 3/27/02 PROJECT NO. 19125 - 279

Location	Occup. (# of people)	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
225	22	76.4	29.6	767	0	8	0
210 (Hall)	10	76.9	29.2	720	0	10	0
223	20	78.5	28.8	707	0	7	0
219	21	77.8	28.9	712	0	9	0
206	-	76.0	27.3	713	0	8	0
206 (Hall)	-	77.3	27.8	737	0	8	0
215	30	77.8	28.8	834	0	12	0
211	23	77.5	29.2	842	0	8	0
207 (Hall)	-	77.7	28.3	754	0	9	0
Hall by stairs	-	77.6	27.3	735	0	7	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.


Signature:  Date: 3/27/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6TIME 1345LOCATION PS 234 M DATE 3/27/02 PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
201		76.0	26.2	624	0	6	0
202 (HALL)		76.4	26.6	628	0	6	0
301	3	75.5	27.6	698	0	76	0
302 (HALL)		76.0	28.0	758	0	12	0
305	30	75.0	28.4	842	0	10	0
304	27	76.2	29.2	808	0	10	0
311	28	74.9	28.3	849	0	9	0
306		75.4	27.9	659	0	7	0
315	26	76.0	27.6	734	0	6	0
308	20	74.8	28.3	739	0	12	0
Guideline levels ASHRAE/AHIA/EPA		68 - 75°F/winter 73 - 79°F/summer	30 - 60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/27/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6TIME 1410LOCATION PS 234 M DATE 3/27/02 PROJECT NO. 19125 - 279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
319	20	74.9	28.1	773	0	7	0
323	22	74.5	28.2	779	0	7	0
325	16	73.5	28.3	843	0	10	0
310	2	74.0	27.6	706	0	6	0
329	1	75.7	27.9	683	0	6	0
312 (Hall)		76.6	26.9	597	0	9	0
316	21	77.0	27.3	640	0	8	0
318	25	76.7	26.5	601	0	9	0
320	24	76.8	26.8	614	0	7	0
322	21	77.2	27.6	710	0	8	0
Guideline levels ASHRAE/AHIA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 3/27/02