

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

**Attn:** Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122**Phone:** (212) 477-8941**Received:** 3/9/02

4:00:00 PM

ATC Group #: 6999**Analysis Date:** 3/9/02**Project:** NYC-BOE PS 234M Project#: 14584-1823

292 Greenwich St., New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5u-5	5u		(S/mm ²)	(S/cc)	
01 6999 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
02 6999 -2	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
03 6999 -3	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
04 6999 -4	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
05 6999 -5	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
06 6999 -6	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
07 6999 -7	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
08 6999 -8	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLMTEM #101187-0, NY State ELAP #10879

CITY_21MC100_002878313

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 3/9/02 4:00:00 PM
 ATC Group #: 6999
 Analysis Date: 3/9/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE PS 234M Project#: 14584-1823
 292 Greenwich St., New York, NY


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
09 6999 -9	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
10 6999 -10	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
11 6999 -11	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
12 6999 -12	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
13 6999 -13	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
14 6999 -14	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
15 6999 -15	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D

Approved by: 

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002878314