

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6TIME 1000LOCATION PS 234 M DATE 2/7/02 PROJECT NO. 19125-279

Location	Occup	Temperature (°C)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	TVOCs (ppm)
Outside Main Entrance		40.1	43.1	477	0	50	0
SW Corner		39.8	43.9	481	1	48	0
NW Corner		39.2	44.3	490	1	47	0
NE Corner		39.0	44.9	499	1	49	0
SE Corner		38.6	45.3	503	1	51	0
Lunch Room.		69.9	34.9	777	0	39	0
Gym.	15	67.6	29.4	845	0	40	0
Hall by Exit 1		68.8	29.8	707	0	41	0
118	22	70.0	30.3	1200	0	33	0
122	21	69.0	28.9	927	0	39	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jiri Chay Date: 2/7/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 6TIME 1030LOCATION PS 234 MDATE 2/7/02PROJECT NO. 19125-279

Location	Room	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Removable Particulate Matter (µg/m³)	TVOCs (ppm)
222	16	70.0	29.8	1009	0	37	0
220	20	71.2	30.8	1170	0	34	0
218	26	72.8	29.9	1061	0	36	0
229	29	72.6	29.5	1887	0	23	0
223	26	75.0	30.9	1502	0	30	0
210 (Hall)	—	73.5	25.8	1099	0	31	0
206 (Assembly)	—	67.1	18.9	544	1	30	0
215	13	72.9	27.3	1437	0	32	0
Stair #2 (Hall)	—	72.0	25.7	1270	0	33	0
201	13	70.1	22.9	1111	0	31	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jay Chang Date: 2/7/02

CITY_21MC100_002878482

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6


TIME 10:50

LOCATION PS 234 M DATE 2/7/02 PROJECT NO. 19125-279

Location	Temp (°F)	Relative Humidity (%)	CO ₂ (ppm)	Carbon Monoxide (ppm)	Radon (pCi/L)	TVOC (ppm)
305	30	70.8	29.6	1819	0	40
304	24	72.0	30.1	1609	0	31
306	8	71.8	28.6	1470	0	30
315	36	71.5	35.5	3102	0	27
308	20	72.1	30.1	1810	0	30
319	19	70.7	31.3	2402	0	21
325	29	70.5	28.6	2102	0	30
316	24	71.1	29.1	1361	0	27
318	26	72.0	30.7	1723	0	27
320	25	72.3	30.8	1682	0	29
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/7/02

CITY_21MC100_002878483

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 6

TIME 1200

LOCATION PS234 M


DATE 2/7/02

PROJECT NO. 19125-279

Location	Occupancy (per)	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	TVOCs (ppm)
Outside Main Entrance		41.0	44.0	485	1	39	0
Outside NW Corner		40.8	45.1	480	1	40	0
Outside NE		40.5	45.8	478	1	45	0
Outside SW		39.7	46.5	486	1	48	0
Outside SE		39.5	46.9	489	1	46	0
Hall by Main Deck	-	74.0	24.5	775	0	39	0
116	10	70.3	24.9	847	0	40	0
118	-	69.9	25.2	869	0	38	0
120	26	70.2	25.5	999	0	32	0
122	28	71.0	24.9	890	0	30	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/7/02

CITY_21MC100_002878484

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6

TIME 1230

LOCATION PS234 M


DATE 2/7/02

PROJECT NO. 19125-279

Location	Occupancy	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	TVOCs (ppm)
222		67.7	28.0	663	0	40	0
220		69.8	28.1	638	0	38	0
218		70.0	27.6	660	0	36	0
229		71.3	28.3	679	6	40	0
223		70.1	27.5	690	0	42	0
210		69.8	27.1	700	0	40	0
215	15	69.9	27.5	790	0	38	0
Stair #2		70.3	28.1	630	0	35	0
201	8	70.4	29.0	809	0	36	0
202	5	68.7	28.5	701	0	28	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 2/7/02

CITY_21MC100_002878485

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6

TIME 12:55

LOCATION PS234 M


DATE 2/7/02

PROJECT NO. 19125-279

Location	Occupancy	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	TVOCs (ppm)
304		70.3	28.4	707	0	29	0
305		71.0	26.8	700	0	31	0
306		74.0	27.0	830	0	38	0
308		73.8	30.0	911	0	40	0
315		72.9	28.8	709	0	36	0
319		70.5	29.0	803	0	35	0
316		71.9	27.8	900	0	30	0
318		71.8	30.1	770	0	28	0
320		70.3	28.6	653	0	30	0
325		72.3	27.9	649	0	33	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 2/7/02

CITY_21MC100_002878486