

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 03-06-02

CLIENT: NYC BOE

PROJECT ADDRESS: P.S. 234M/292 Greenwich St
NY, NY 10007

PROJECT NO: 41617-0555
SAMPLED BY: Yiannis Efstahiou

SAMPLE DATE: 03-05-02
DATE RECEIVED: 03-05-02
DATE ANALYZED: 03-05-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
01	9712	Small Playground Center (Ground Concrete Surface)	<9.0	9.0
02	9712	Small Playground East Side (Ground Concrete Surface)	13.2	9.0
03	9712	Small Playground South Side (Ground Concrete Surface)	<9.0	9.0
04	9712	Outside by Main Entrance (Ground Concrete Surface)	<9.0	9.0
05	9712	Outside North of Main Entrance (Ground Concrete Surface)	<9.0	9.0
06	9712	Outside South of Main (Ground Concrete Surface)	<9.0	9.0
07	9712	Large Playground West Side (Ground Concrete Surface)	<9.0	9.0
08	9712	Large Playground Center (Ground Concrete Surface)	16.5	9.0
09	9712	Large Playground North Side (Ground Concrete Surface)	<9.0	9.0
10	9712	Large Playground South Side (Ground Concrete Surface)	<9.0	9.0
11	9712	Large Playground East Side (Gournd Concrete Surface)	<9.0	9.0
12	9712	1st Floor Hallway by Elevator Floor	<9.0	9.0
13	9712	Cafeteria Floor	<9.0	9.0
14	9712	Auditorium Floor	<9.0	9.0

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

15	9712	Gymnasium Floor	~	<9.0	9.0
16	9712	Classroom 223 Facing South Window Sill	—	<7.3	7.3
17	9712	Classroom 315 Facing South Floor	,	<9.0	9.0
18	9712	Classroom 202 Facing South Window Sill	—	<7.3	7.3
19	9712	Classroom 304 Floor	.	<9.0	9.0
20	9712	Classroom 329 Floor	,	<9.0	9.0
21	9712	Classroom 316 Floor	,	<9.0	9.0
22	9712	Classroom 318 Floor	,	<9.0	9.0
23	9712	Classroom 320 Floor	-	<9.0	9.0
24	9712	Classroom 213 Floor	-	<9.0	9.0
25	9712	Classroom 211 Floor	-	<9.0	9.0
26	9712	Classroom 216 Floor	~	<9.0	9.0
27	9712	Classroom 218 Floor	~	<9.0	9.0
28	9712	Classroom 220 Floor	~	<9.0	9.0
29	9712	Classroom 116 Floor	^	<9.0	9.0
30	9712	Classroom 118 Floor	~	<9.0	9.0
31	9712	Classroom 120 Floor	~	<9.0	9.0
32	9712	Classroom 122 Floor	~	106.6	9.0
33	9712	PTA Office Floor	~	<9.0	9.0
34	9712	Blank		<9.0 µg	9.0 µg
35	9712	Blank		<9.0 µg	9.0 µg
36	9712	Blank		<9.0 µg	9.0 µg
37	9707	Blank		<9.0 µg	9.0 µg

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:
 HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft²,
 Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:
 Blank units are in µg

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).