


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8TIME 8:00LOCATION PS89 M DATE 2/4/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
North Playground		54.2	21.2	501	0	49	0
South Playground		54.0	21.8	504	0	51	0
Exit North		54.1	21.1	509	0	50	0
NW Corner		53.8	21.5	498	0	51	0
NE Corner		53.1	21.9	495	0	52	0
SW Corner		52.9	22.1	508	0	50	0
SE Corner		53.0	22.5	500	0	48	0
Exit South		53.7	22.7	499	0	49	0
Inside North Exit		68.5	27.6	529	0	29	0
Inside South Exit		68.0	28.0	535	0	31	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 2/4/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 8TIME 8:30LOCATION PS89 M DATE 2/4/02 PROJECT NO. 19125-297

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Cafeteria		68.2	23.1	561	0	29	0
Hall by Cafeteria Entrance		67.7	21.7	535	0	31	0
Hall by Elevator		68.1	20.8	550	0	35	0
501 (Hall)		69.8	19.7	575	0	22	0
502	30	73.2	21.0	714	0	34	0
508	31	71.6	23.5	1107	0	26	0
512	2	71.5	19.6	692	0	30	0
528	29	71.8	18.4	925	0	28	0
Library	3	71.0	18.0	598	0	24	0
419	—	68.8	17.5	540	0	27	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____


The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.Signature: Ji Chen Date: 2/4/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 8TIME 9:00LOCATION PS89 M DATE 2/4/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
432	—	70.2	17.6	500	0	26	0
(Hall) 430	—	69.7	17.7	550	0	27	0
426	—	69.0	17.3	540	0	27	0
410 (Hall)		69.1	18.0	610	0	26	0
408	27	69.9	22.2	799	0	24	0
404	26	70.7	19.9	865	0	24	0
402	30	70.2	23.2	1109	0	24	0
301	—	69.7	17.9	555	0	20	0
302 (Hall)	—	69.2	17.5	526	0	28	0
306	—	69.0	17.6	513	0	26	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 2/4/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 8


TIME 9:30

LOCATION PS89 M DATE 2/4/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Gym	—	68.3	17.5	515	0	27	0
316 (Hall)	—	68.0	17.6	514	0	28	0
326	3	68.2	17.8	530	0	29	0
328	—	67.9	17.6	518	0	28	0
330	—	68.3	17.8	513	0	28	0
(2nd Fl) Stairs #1	—	67.8	18.1	519	0	30	0
232	—	66.8	18.3	500	0	18	0
Auditorium	—	67.7	17.8	505	0	24	0
204	—	68.8	19.1	520	0	30	0
201 (Hall)	—	68.9	18.2	525	0	25	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 2/4/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8TIME 1400LOCATION PS89 M DATE 2/4/02 PROJECT NO. 19125-297

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
North Playground		49.2	20.3	459	0	28	0
South Playground		49.0	20.8	460	0	30	0
Exit North		48.3	20.5	465	0	26	0
Exit South		48.2	20.1	467	0	24	0
NW Corner		49.0	20.8	500	0	28	0
NE Corner		48.5	20.5	519	0	30	0
SW Corner		47.3	20.7	509	0	31	0
SE Corner		47.0	20.9	521	0	25	0
Inside North		72.0	27.9	564	0	16	0
Inside South		72.2	27.4	575	0	14	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jing Chen Date: 2/4/02

ATC ASSOCIATES, INC.


Page 6 of 8TIME 14/30

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS89M DATE 2/4/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Hall by Cafeteria		72.6	24.4	564	0	17	0
Hall by Elevator		72.0	24.2	551	0	16	0
508 (Hall)		71.9	19.2	628	0	14	0
402	3	69.9	18.4	589	0	20	0
501	3	72.9	20.9	576	0	9	0
502 (Hall)	—	72.0	20.4	608	0	14	0
504	7	72.5	21.3	719	0	22	0
510	5	71.8	19.3	644	0	19	0
526	—	71.1	18.3	660	0	17	0
528	—	70.4	17.9	596	0	16	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 2/4/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8TIME 1500LOCATION PS89 M DATE 2/4/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
432 (Hall)		69.2	16.8	556	0	14	0
428		68.7	16.9	530	0	12	0
426		69.0	17.3	532	0	15	0
410 (Hall)		68.9	17.0	553	0	15	0
408	9	70.1	19.6	599	0	15	0
406	6	70.4	18.6	738	0	14	0
401	2	71.2	17.8	577	0	11	0
301	—	71.9	16.7	535	0	14	0
302	—	70.4	17.4	523	0	18	0
304 (Hall)	—	69.8	16.6	504	0	19	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____


The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jin Chen Date: 2/4/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8TIME 1530LOCATION PS89M DATE 2/4/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
306		69.5	16.5	495	0	12	0
Gym (Hall)		68.9	16.2	491	0	18	0
326		69.0	16.7	484	0	15	0
328		68.9	16.5	483	0	16	0
219 (Hall)		67.8	16.3	486	0	14	0
232		67.4	17.1	470	0	11	0
228 (Hall)		68.1	16.5	555	0	14	0
Hall by Elevator		68.8	16.4	488	0	14	0
204		69.1	16.8	495	0	17	0
201 (Hall)		69.6	16.4	488	0	14	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 2/4/02