

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8TIME 800LOCATION P589 M DATE 2/13/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Playground North		43.8	23.8	482	2	30	0
" South		43.6	24.0	486	2	29	0
Outside NE Corner		44.0	24.3	493	1	32	0
" NW "		46.3	24.8	491	1	32	0
" SE "		45.0	25.0	490	1	31	0
" SW "		44.1	25.3	488	1	30	0
" North Exit		43.5	25.8	492	1	29	0
" South "		43.0	26.1	489	1	31	0
Inside South Exit		74.0	23.1	598	0	17	0
Inside North Exit		73.8	23.0	594	0	18	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: Working on the Street by PlaygroundThe assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jing Chen Date: 2/13/02

CITY_21MC100_003775226

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 8TIME 830LOCATION P589 M DATE 2/13/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
501	—	71.9	18.3	556	0	11	0
502	—	74.1	18.0	620	0	15	0
504	1	72.2	18.0	700	0	18	0
506	30	71.9	21.3	948	0	17	0
508	32	71.1	20.9	931	0	18	0
515 (Hall)	—	70.7	18.7	746	0	17	0
512	2	71.0	18.4	669	0	18	0
526	32	72.2	19.2	716	0	13	0
517 (Library)	1	70.9	17.0	586	0	12	0
519 (Hall)	—	70.6	18.4	673	0	14	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 2/13/02

CITY_21MC100_003775227

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 8TIME 900LOCATION PS89M DATE 2/13/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
419	5	69.6	17.1	504	0	13	0
428 (Hall)	—	69.3	16.9	504	0	15	0
426	—	69.4	16.8	485	0	13	0
410 (Hall)	—	69.2	18.2	632	0	14	0
408	28	69.4	20.8	759	0	16	0
406 (Hall)	—	69.4	19.1	657	0	16	0
404	31	72.0	22.1	948	0	14	0
402	31	70.0	20.4	899	0	13	0
401 (Hall)	—	69.8	19.2	678	0	12	0
Hall by Elevator	—	70.1	18.6	681	0	16	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jim Chay Date: 2/13/02

CITY_21MC100_003775228


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 8TIME 930LOCATION PS89 M DATE 2/13/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
301		68.3	18.9	538	0	9	0
306 (Hall)		68.0	19.0	520	0	11	0
Gym		67.6	19.1	528	0	12	0
316		67.3	18.2	498	0	13	0
326		70.1	18.5	501	0	9	0
230 (Hall)		69.4	18.4	511	0	11	0
226	-	69.9	18.8	501	0	13	0
Auditorium	-	69.5	17.6	499	0	10	0
201 (Hall)		69.4	17.5	490	0	10	0
Cafeteria	-	72.4	20.5	598	0	16	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/13/02

CITY_21MC100_003775229


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8TIME 2/1400LOCATION P589 M DATE 2/13/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Playground North		38.4	13.8	450	0	9	0
" South		38.9	14.2	449	0	10	0
Outside NW Corner		38.3	14.0	451	0	12	0
" NE "		38.0	14.3	449	0	11	0
" SW "		38.3	14.5	453	0	10	0
" SE "		38.6	14.9	456	0	12	0
" North Exit		38.8	15.1	459	0	11	0
" South "		38.6	15.3	458	0	10	0
* Inside North Exit		77.8	13.5	514	0	6	0
* Inside South "		77.6	13.4	510	0	5	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: Working on the Street.

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/13/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 8TIME 1430LOCATION P589 M DATE 2/13/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Cafeteria		72.9	11.5	512	0	5	0
Hall by Elevator		72.4	11.1	482	0	7	0
501	30	74.4	14.5	728	0	8	0
502	—	75.6	13.2	610	0	5	0
504 (Hall)	—	73.5	12.8	585	0	11	0
4A	—	68.8	12.3	497	0	6	0
432	—	68.9	12.5	489	0	9	0
428	—	68.4	11.8	494	0	5	0
410 (Hall)	—	69.4	12.2	545	0	8	0
401 (Hall)	—	70.3	13.0	670	0	6	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 2/13/02

CITY_21MC100_003775231

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8TIME 1500LOCATION P589 M DATE 2/13/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
328 (Hall)		68.7	11.0	442	0	5	0
Stair 2 (Hall)		68.6	11.1	472	0	6	0
316 (Hall)		68.4	11.0	473	0	6	0
310		68.0	12.3	475	0	6	0
Gym		67.8	12.0	476	0	5	0
308		67.6	12.1	528	0	7	0
306 (Hall)		67.8	11.9	473	0	5	0
302 (Hall)		68.5	11.4	473	0	6	0
301		69.7	11.6	515	0	5	0
Hall by Elevator		69.6	12.2	488	0	6	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 2/13/02

ATC ASSOCIATES, INC.


Page 8 of 8TIME 1530

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS89M DATE 2/13/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
332 (HALL)		69.5	11.5	473	0	7	0
319	-	69.3	11.3	464	0	5	0
Stairs #1		70.5	11.8	494	0	5	0
219 (HALL)		70.8	11.7	503	0	4	0
228 (HALL)		70.5	11.1	480	0	4	0
226	-	70.4	11.4	460	0	8	0
Auditorium	-	71.0	10.3	466	0	5	0
204 (HALL)		72.1	11.3	479	0	6	0
Hall by Stair 3		72.4	11.6	480	0	6	0
201 (HALL)		72.7	11.8	504	0	6	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 2/13/02