

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 5

TIME 14:30

LOCATION M89 DATE 1/29/02 PROJECT NO. 19125-297

Location	Temp (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Formaldehyde (ppb)	VOCs (ppm)
(North) Outside Playground	68.1	38.4	472	0	49	0
(South) Playground	68.2	38.4	475	0	50	0
Outside North Exit	67.9	38.0	501	0	48	0
Outside South Exit	67.5	38.1	492	0	49	0
Outside NW Corner	67.9	38.2	490	0	51	0
Outside SW Corner	67.1	38.3	489	0	50	0
Outside NE Corner	66.9	38.1	479	0	49	0
Outside SE Corner	67.2	37.9	499	0	50	0
(Exit) Inside North	70.3	38.4	539	0	40	0
(Exit) Inside South	72.3	37.8	531	0	46	0
Guideline levels ASHRAE/AIHA/EPA	68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: Jing Chen Date: 1/29/02

CITY_21MC100_003775373


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 5TIME 14:45LOCATION PS89M DATE 1/29/02 PROJECT NO. 19125-2897

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Particulate (µg/m³)	TVOC (ppm)
Cafeteria		71.9	37.6	519	0	40	0
Hall by Elevator		72.3	37.1	525	0	41	0
501		75.3	36.0	598	0	29	0
502 (Hall)		75.4	36.9	620	0	40	0
505 (Hall)		75.0	36.8	618	0	43	0
506		75.3	36.6	813	0	44	0
508 (Hall)		75.0	35.8	660	0	45	0
526	1	75.1	35.1	599	0	38	0
528	15	74.7	36.7	840	0	47	0
519		74.5	34.9	719	0	37	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 1/29/02

CITY_21MC100_003775374

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 5

TIME 15:00

LOCATION 89M DATE 1/29/02 PROJECT NO. 19125-0297

Location	Occupancy	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Particulate (µg/m³)	VOC (ppm)
419		73.2	34.1	589	0	38	0
432 (Hall)		73.0	34.2	569	0	40	0
426	21	73.4	35.4	791	0	35	0
Hall by stair 2		73.4	35.1	675	0	40	0
410 (Hall)		73.5	35.2	650	0	40	0
408	2	74.1	35.0	746	0	36	0
407 (Hall)	—	74.1	35.1	701	0	40	0
404	10	74.5	35.6	781	0	41	0
401 (Hall)		74.7	35.1	670	0	40	0
Hall by stair 3		74.8	35.2	677	0	39	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jing Chen Date: 1/29/02

CITY_21MC100_003775375

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 5TIME 15:25LOCATION PS 89M DATE 1/29/02 PROJECT NO. 19125-2097

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	TVOCs (ppm)
301 (Hall)		74.1	33.5	559	0	49	0
304 (Hall)		74.2	33.5	558	0	48	0
Elevator (Hall)		74.4	33.6	570	0	47	0
Gym		74.0	33.9	593	0	35	0
310		73.7	33.6	560	0	40	0
Stair #2		73.5	33.3	569	0	41	0
326 (Hall)		73.4	33.4	571	0	40	0
328 (Hall)		73.2	33.6	560	0	41	0
330 (Hall)		73.0	33.7	555	0	38	0
Stair #1		72.6	33.2	567	0	40	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____ Date: 1/29/02

CITY_21MC100_003775376

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 5

TIME 16:00

LOCATION PS89M DATE 1/29/02 PROJECT NO. 19125-2897

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	TVOCs (ppm)
219 (Hall)		72.1	33.1	573	0	43	0
232 (Hall)		72.3	34.0	567	0	42	0
228 (Hall)		72.5	34.3	547	0	40	0
Outside Auditorium (Hall)		72.9	34.5	550	0	42	0
226		73.3	34.0	529	0	49	0
Hall by stair 2		72.6	34.1	520	0	45	0
Inside Auditorium		73.7	33.0	628	0	44	0
207 (Hall)		73.6	34.0	539	0	45	0
201 (Hall)		73.6	33.8	524	0	40	0
202		73.8	33.0	525	0	48	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jin Chen Date: 1/29/02

CITY_21MC100_003775377