

New York Environmental & Analytical Laboratories, Inc.

an independent full service testing & consulting firm

88 Harbor Road
Port Washington, NY 11050
Tel. (516) 944-9500 Fax. (516) 944-9507

CLIENT: ATC ASSOCIATES, INC.
104 EAST 25TH STREET, 10TH
NEW YORK, NY 10010

REPORT #: 220658
PROJECT #: 031102LC

SAMPLE DATE: 03/11/02


ANALYSIS DATE: 03/11/02

PROJECT: M833

REPORT DATE: 03/12/02

ANALYTICAL REPORT for METALS IN DRINKING WATER (STANDARD METHODS 18TH EDITION)

SAMPLE NO	SAMPLE LOCATION	Pb (ug/L)	Cu (ug/L)	Fe (ug/L)	Zn (ug/L)	Mn (ug/L)
M833-01M	fountain, 10th floor hallway	6	327	106	270	24
M833-02M	fountain, 10th floor hallway	1	126	21	60	27
M833-03M	fountain, 9th floor hallway	1	124	37	60	12
M833-04M	fountain, 9th floor hallway	<1	122	32	60	25
M833-05M	fountain, 8th floor cafeteria	<1	105	36	40	17
M833-06M	fountain, 8th floor cafeteria	<1	106	21	40	21
M833-07M	kitchen sink	6	665	385	500	90
M833-08M	kitchen sink	3	583	314	470	97
M833-09M	fountain, 6th floor hallway	5	591	204	590	58
M833-10M	fountain, 6th floor hallway	6	682	257	520	55
M833-11M	fountain, 3rd floor hallway	<1	197	11	60	<10
M833-12M	fountain, 3rd floor hallway	2	261	36	60	<10
M833-13M	fountain, 2nd floor hallway	<1	111	48	20	<10
M833-14M	fountain, 2nd floor hallway	<1	109	39	30	<10
M833-15M	-blank-	<1	<10	<10	<10	<10


Li Tsang
Laboratory Director

LT/lg;