

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

EMSL

Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018
Fax: (212) 221-7840 Phone: 212-221-7822
Project: 35052-0000-00017 / New York City Department / 100
Church St. / Ambient

Customer ID: TRCE51
Customer PO:
Received: 02/28/03 3:55 PM
EMSL Order: 030303182
EMSL Project ID:
Analysis Date: 2/28/2003

**Phase Contrast Microscopy (PCM) Fiber Count by NIOSH 7400, Fourth Edition, Issue 2,
8/15/94**

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ²	Fibers/ cc	Notes
ZD022803ASBAI R2001	20th Floor Exit to North Corridor	2/28/2003	1533.33	<5.5	100	0.002	<7.0	<0.002	
030303182-0001									
ZD022803ASBAI R2002	20th Floor Exit to South Corridor	2/28/2003	1527.02	<5.5	100	0.002	<7.0	<0.002	
030303182-0002									
ZD022803ASBAI R2003	20th Floor Exit to North Corridor	2/28/2003	1520.71	<5.5	100	0.002	<7.0	<0.002	
030303182-0003									
ZD022803ASBAI R2004	20th Floor Exit to South Corridor	2/28/2003	1527.02	<5.5	100	0.002	<7.0	<0.002	
030303182-0004									
ZD022803ASBAI RFB05	Blank	2/28/2003	0.00	<5.5	100		<7.0		Field Blank
030303182-0005									

Zena Mezheritsky

Analyst

José ArriagaLaboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report
relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11506, AIHA #102581)

PCM2

1