

03/05/2003 22:56 212-290-2538

EMSL ANALYTICAL INC

PAGE 01/02

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com



Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018

Fax: (212) 221-7840

Phone: 212-221-7822

Project: 36052-0000-00017 / New York City Law Department / 100
Church St. / Ambient

Customer ID: TRCE51

Customer PO:

Received: 03/05/03 3:55 PM

EMSL Order: 030303456

EMSL Project ID:

Analysis Date: 3/5/2003

**Phase Contrast Microscopy (PCM) Fiber Count by NIOSH 7400, Fourth Edition, Issue 2,
8/15/94**

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ²	Fibers/ cc	Notes
ZD030503ASBAI R2001	20th Floor Entrance to North Corridor	3/5/2003	1533.33	<5.5	100	0.002	<7.0	<0.002	
030303456-0001									
ZD030503ASBAI R2002	20th Floor Entrance to South Corridor	3/5/2003	1539.69	<5.5	100	0.002	<7.0	<0.002	
030303456-0002									
ZD030503ASBAI R2003	20th Floor Entrance to North Corridor	3/5/2003	1533.30	9.0	100	0.002	11.46	0.003	
030303456-0003									
ZD030503ASBAI R2004	20th Floor Entrance to South Corridor	3/5/2003	1527.02	<5.5	100	0.002	<7.0	<0.002	
030303456-0004									
ZD030503ASBAI RFB05	Blank	3/5/2003	0.00	<5.5	100		<7.0		Field Blank
030303456-0005									

Jeremy Robertson

Analyst

Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11508, AIHA #102681)

PCM2

1

CITY_21MC100_011233060