

TOTAL P.09

INDOOR AIR QUALITY

Location	Temp. Standard= 68-74° F.	RH% Standard= 30-50%	CO ₂ Standard= 800-1,00 PPM	CO Standard= 0-9.0 PPM	Dust Particulate Standard= 15,000 ug
September 19, 2001					
Roof	78.8	43.8	371	1.3	78.3
9 th fl.	75.8	43.6	595	1.4	65.4
8 th fl.	79.1	39.8	654	1.2	62.8
7 th fl.	78.9	39.7	590	1.4	59.1
6 th fl.	79.4	39.7	492	1.3	60.1
5 th fl.	78.4	39.4	526	1.3	62.0
4 th fl.	79.2	38.8	579	1.3	59.1
3 rd fl.	77.1	36.2	580	1.2	57.6
2 nd fl.	75.2	43.7	527	1.2	60.1
1 st fl.	75.5	44.7	501	1.3	59.2
1 st fl. Lobby	76.0	45.6	537	1.5	65.0
Ambient-sidewalk	75.8	51.1	372	1.3	116.7

RH= Relative Humidity CO₂=Carbon Dioxide CO= Carbon Monoxide
PPM= Parts Per Million ug= Microgram

