

SciLab Job #: 202012903

Client Name: TRC Environmental Corporation

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (ASTM 5755 Dust)

35052-0000-00002; New York City Law Department; 100 Church Street

SciLab Sample #	Client Sample #	Surface Area Sampled (sq. cm)	Dilution Factor	Asbestos Structures Detected	* Analytical Sensitivity on Grid (Str / sq mm)	Structure Density on Grid (Str / sq mm)	* Analytical Sensitivity on Surface (Str / sq. cm)	Structure Density on Surface (Str / sq. cm)	Type of Asbestos
15	JD011802MV0203 Microvac Sample - Supplemental Supply Duct	100.0	0.100	0	25	<25	535	<535	NSD
16	JD011802MV2001 Microvac Sample - Ceiling Tile 20th Floor	100.0	0.020	24	10	240.0	1,070	25,680	chrysotile
17	JD011802MV2002 Microvac Sample - Inductor Unit - 20th Floor	100.0	0.020	1	10	10.0	1,070	1,070	chrysotile
18**	JD011802MVBLANK1 Microvac Blank Sample 1				I				
19**	JD011802MVBLANK2 Microvac Blank Sample 2				I				

* structure density represented by the detection of 1 structure

** not analyzed

NSD: No Asbestos Structures Detected

Reviewed By:

Analyzed By:

Mark Peysakhov

Date: 11/23/02

JPN-27-2002 11:20

SCIENTIFIC LABS

212 679 9392 P.03/05

CITY_21MC100_006518794