

Client Name: TRC Environmental Corporation

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)
 35052-0000-00002; New York City Law Department; 100 Church Street, New York, NY

SciLab Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)			Structure Density (struc/sq. mm.)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>5.0	Total	>5.0	Total	>5.0	Total	
15	SN01102ASBAIR2009 Center Hallway East		1527	.06	0.0042	0.0	0.0	0.0	<16.7	<16.7	<0.0042	<0.0042	NSD
16	SN01102ASBAIR2010 Center Hallway West		1519	.06	0.0042	0.0	0.0	0.0	<16.7	<16.7	<0.0042	<0.0042	NSD
17	SN01102ASBAIR0601 SW Corner		1699	.05	0.0045	0.0	0.0	0.0	<20	<20	<0.0045	<0.0045	NSD
18	SN01102ASBAIR0602 South Wall Middle		1699	.05	0.0045	0.0	0.0	0.0	<20	<20	<0.0045	<0.0045	NSD
19	SN01102ASBAIR0603 SE Corner		1690	.05	0.0046	0.0	0.0	0.0	<20	<20	<0.0046	<0.0046	NSD
20	SN01102ASBAIR0604 East Wall Middle		1527	.06	0.0042	0.0	0.0	0.0	<16.7	<16.7	<0.0042	<0.0042	NSD
21	SN01102ASBAIR0605 NE Corner		1604	.05	0.0046	0.0	0.0	0.0	<20	<20	<0.0046	<0.0046	NSD
22	SN01102ASBAIR0606 North Wall Middle		1465	.06	0.0044	0.0	0.0	0.0	<16.7	<16.7	<0.0044	<0.0044	NSD
23	SN01102ASBAIR0607 NW Corner		1503	.06	0.0043	0.0	0.0	0.0	<16.7	<16.7	<0.0043	<0.0043	NSD
24	SN01102ASBAIR0608 West Wall Middle		1493	.06	0.0043	0.0	0.0	0.0	<16.7	<16.7	<0.0043	<0.0043	NSD
25	SN01102ASBAIR0609 Center Hallway West		1471	.06	0.0044	0.0	0.0	0.0	<16.7	<16.7	<0.0044	<0.0044	NSD
26	SN01102ASBAIR0610 Center Hallway East		1602	.05	0.0048	0.0	0.0	0.0	<20	<20	<0.0048	<0.0048	NSD
27	SN01102ASBAIR0501 SW Corner		1919	.05	0.0040	0.0	0.0	0.0	<20	<20	<0.0040	<0.0040	NSD
28	SN01102ASBAIR0502 South Wall Middle		1669	.05	0.0046	0.0	0.0	0.0	<20	<20	<0.0046	<0.0046	NSD

Interpretation represented by the detection of 1 structure
 analyzed

No Asbestos Structures Detected

Reviewed By: _____

Analyzed By: _____

Date: 1/14/02

Aleksandr Baranovskiy

APP: 200346-0

01/16/2002 17:33 212-349-4648

TRC ENVIRONMENTAL CO

PAGE 03/23

CITY_21MCM100_002830721