NYC 9/11 Public Portal Document

Ambient Group, Inc.
10 Morris Avenue,
Glen Cove 11542
(516) 609-0009

ELAP 10865

AIRBORNE ASBESTOS STRUCTURES RESULTS
(TRANSMISSION ELECTRON MICROSCOPY - TEM)

J. RESNICK & SONS
75 PARK PLACE
PROJECT ID: 211658
DATE COLLECTED:

SAMPLE NUMBER	LAB SAMPLE ID	SAMPLE LOCATION	ASBESTOS STRUCTURES cm^3
211358-01 FIELD SHT 6063	AEM990 12397	12/27/01 – 11:03 AM 10th Floor: IWA/Northside Opposite Window LT ANYL SENS	<0.0045
211358-02 FIELD SHT 6063	AEM990 12398	12/27/01 – 11:04 AM 10th Floor: IWA/Southside Opposite Window LT ANYL SENS	<0.0045
211358-03 FIELD SHT 6063	AEM990 12399	12/27/01 – 11:06 AM 10th Floor: IWA/Westside Opposite Window LT ANYL SENS	<0.0045
211358-04 FIELD SHT 6063	AEM990 12400	12/27/01 – 11:08 AM 10th Floor: IWA/Eastside Opposite Window LT ANYL SENS	<0.0045
211358-05 FIELD SHT 6063	AEM990 12401	12/27/01 – 11:10 AM 10th Floor: IWA/Middle Area LT ANYL SENS	<0.0045
211358-06 FIELD SHT 6058	AEM990 12402	12/27/01 – 11:12 AM 10th Floor: IWA/Southwest Corner, Opposite Window LT ANYL SENS	<0.0045
211358-07 FIELD SHT 6058	AEM990 12403	12/27/01 – 11:14 AM 10th Floor: IWA/Northwest, Opposite Window/Corner LT ANYL SENS	<0.0045

LT ANAL SENS=LESS THAN ANALYTICAL SENSITIVITY
ANALYTICAL SENSITIVITY=0.0049

CITY_21MC100_008853996

NYC-WTC_000220016