NYC 9/11 Public Portal Document

MORETRENCH AMERICAN CORPORATION
www.moretrench.com

100 Stickle Avenue
P.O. Box 316
Rockaway, N.J. 07866
Tel: (973) 627-2100
Fax: (973) 627-3950 / 627-6078

January 14, 2002

FAXED 1-14-02 12:45pm

Serial Letter 01-4906-32

VIA FACSIMILE
(212) 968-1284

3 pages

Mr. Brian Peters
Bovis Lend Lease LMB, Inc.
52 Chambers Street
New York, NY 10007

RE: World Trade Center Dewatering
Contract No. 20020004649
Water Quality Analysis

Dear Brian:

Included in this fax transmission are water quality analyses for samples of the dewatering discharge (Main Discharge) and the sumping discharge (South Discharge) which were taken on December 31, 2001.

The MTBE concentration in the sumping water sample has risen to 200 pp/b. The MTBE concentration in the dewatering discharge has dropped to 18 pp/b. Both of these readings are in excess of the 10 pp/b maximum allowable concentration for discharges to the New York City Sewer System..

Very truly yours,
MORETRENCH AMERICAN CORPORATION

John F. Donohoe /sk
John F. Donohoe
President

JFD:sk

cc: Mr. William Klingler/Moretrench

X/Contract Jobs/4000/4900/4906/Serrial Letters