

SciLab Job# **99-01-5858**
 Client Name **Warren & Panzer Engineering, P C**

Table 1
Summary of Bulk Asbestos Analysis Results

822 18 01, DDC, Wild Life Health Center

SciLab Sample #	Client Sample# Location	HG Area	Sample Weight (g/1m)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
01	822 18 01 03-01 10 1%	03	—	—	—	—	NA	NAD
02	822 18 01 03-02 15 5%	03	—	—	—	—	NA	NAD
03	822 18 01 03-03 10 9%	03	—	—	—	—	NA	NAD
04	822 18 01 04-01 9 5%	04	—	—	—	—	NA	NAD
05	822 18 01 04-02 10 9%	04	—	—	—	—	NA	NAD
06	822 18 01 04-03 23 3%	04	—	—	—	—	NA	NAD
07	822 18 01 07-01 10 8%	07	—	—	—	—	NA	NAD
08	822 18 01 07-02 11 4%	07	—	—	—	—	NA	NAD

Reviewed by



PLM analyst

TLM analyst Louis Lombardi



Quantification should be considered qualitative only (positive or negative) for beginning sample weights of less than 0.1 grams. NAD = no asbestos detected. NA = not analyzed. NVA = no visible asbestos. Trace = <1%. NAPS = not analyzed positive stop. Bulk Asbestos Analysis - PLM per 40 CFR 763 Subpt 1 Appd A. TLM by Chitfield and ELAP Analysis Protocol PLM 198.1/TEM 198.4 for New York samples (ELAP# 11480). Note: TEM resolves all asbestos fibers whereas PLM typically will not resolve fibers <~0.2 microns in diameter.

Reviewed By

SciLab Job# 99-01-5858
 Client Name Warren & Panzer Engineering, P C

Table I
Summary of Bulk Asbestos Analysis Results

822 18 01, DDC Wild Life Health Center

SciLab Sample #	Client Sample# Location	HG Arc 1	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
09	822 18 01 07-03 10 3%	07	—	—	—	—	NA	NAD
10	822 18 01 09-01 2 3%	09	—	—	—	—	NA	Chrysotile Trace
11	822 18 01 09-02 1 5%	09	—	—	—	—	NA	NAD
12	822 18 01 09-03 2 5%	09	—	—	—	—	NA	NAD
13	822 18 01 11-01 14 7%	11	—	—	—	—	NA	NAD
14	822 18 01 11-02 10 9%	11	—	—	—	—	NA	NAD
15	822 18 01 11-03 9 7%	11	—	—	—	—	NA	NAD
16	822 18 01 12-01 10 9%	12	—	—	—	—	NA	NAD

Reviewed by Dr. G. R.

PLM analyst _____

TEM analyst Louis Lombardi San H. Hui

Quantification should be considered qualitative only (positive or negative) for beginning sample weights of less than 0.1 grams. NAD = no asbestos detected. NA = not analyzed. NVA = not visible asbestos. Trace = <1%. NAPS = not analyzed positive stop Bulk Asbestos Analysis. PLM per 40 CFR 763 Subpt 1 Appd A. TEM by Chatfield and LLAP Analysis Protocol. PLM 198.1/TEM 198.4 for New York samples (ELAP# 11480). Note: TEM resolves all asbestos fibers whereas PLM typically will not resolve fibers <~0.2 microns in diameter.

Reviewed By _____


SciLab Job# 99-01-5858
 Client Name Warren & Panzer Engineering, P C

Table I
Summary of Bulk Asbestos Analysis Results

822 18 01, DDC, Wild Life Health Center


SciLab Sample #	Client Sample# Location	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
17	822 18 01 12-02 31.5%	12	—	—	—	—	NA	NAD
18	822 18 01 12-03 36.9%	12	—	—	—	—	NA	NAD
19	822 18 01 13-01 42.9%	13	—	—	—	—	NA	NAD
20	822 18 01 13-02 35.7%	13	—	—	—	—	NA	NAD
21	822 18 01 13-03 34.3%	13	—	—	—	—	NA	NAD
22	822 18 01 14-01 5.1%	14	—	—	—	—	NA	NAD
23	822 18 01 14-02 9.2%	14	—	—	—	—	NA	NAD
24	822 18 01 14-03 9.4%	14	—	—	—	—	NA	NAD

Reviewed by



PLM analyst

TEM analyst Louis Lombardi



Quantification should be considered qualitative only (positive or negative) for beginning sample weights of less than 0.1 grams. NAD = no asbestos detected. NA = not analyzed. NVA = no visible asbestos. Trace = <1%. NAPS = not analyzed positive stop Bulk Asbestos Analysis. PLM per 40 CFR 763 Subpt I Appd A. TEM by Chatfield and LLAP Analysis Protocol. PLM 198 1/TEM 198 4 for New York samples (ELAP# 11480). Note: TEM resolves all asbestos fibers whereas PLM typically will not resolve fibers <0.2 microns in diameter.

Reviewed By

SciLab Job# 99-01-5858
 Client Name Warren & Panzer Engineering, P C

Table 1
Summary of Bulk Asbestos Analysis Results

822 18 01, DDC, Wild Life Health Center

SciLab Sample #	Client Sample# Location	HG Acid	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
25	822 18 01 15-01 15 4%	15	—	—	—	—	NA	NAD
26	822 18 01 15-02 10 9%	15	—	—	—	—	NA	NAD
27	822 18 01 15-03 13 4%	15	—	—	—	—	NA	NAD

Reviewed by

PREIL

PLM analyst

TLM analyst Louis Lombardi

[Signature]

Quantification should be considered qualitative only (positive or negative) for beginning sample weights of less than 0.1 grams. NAD = no asbestos detected. NA = not analyzed. NVA = not visible asbestos. Trace = <1%. NAPS = not analyzed positive stop. Bulk Asbestos Analysis - PLM per 40 CFR 763 Subpt F Appd A. TEM by Chatfield and ELAP Analysis Protocol PLM 198.1/TEM 198.4 for New York samples (ELAP# 11480). Note: TEM resolves all asbestos fibers whereas PLM typically will not resolve fibers <~0.2 microns in diameter.

Reviewed By