



228 East 45th Street  
10th Floor  
New York NY 10017  
Tel (212) 922 0689  
Fax (212) 922 0630

AIR SAMPLE ANALYSIS REPORT  
PHASE CONTRAST MICROSCOPY

|                   |                                                                                                                   |                 |         |
|-------------------|-------------------------------------------------------------------------------------------------------------------|-----------------|---------|
| CLIENT            | WARREN & PANZER ENGINEERS P C                                                                                     | TURNAROUND TIME | ASAP    |
| WFP FILE #        | 501 01                                                                                                            | SAMPLE DATE     | 5/29/98 |
| WKP LOG I D #     | A980601                                                                                                           | RECEIVED DATE   | 6/1/98  |
|                   |                                                                                                                   | ANALYSIS DATE   | 6/1/98  |
|                   |                                                                                                                   | REPORT DATE     | 8/28/98 |
| CLIENT JOB        | NYC DDC                                                                                                           |                 |         |
| CLIENT JOB #      | 821 69 01                                                                                                         |                 |         |
| LOCATION          | HUNTS POINT LIBRARY BASEMENT/BOILER RM                                                                            |                 |         |
| ANALYSIS          | AIRBORNE FIBER COUNTING PHASE CONTRAST MICROSCOPY NIOSH 7400<br>NIOSH PAT Lab NO 07186 NY STATE ELAP Lab NO 11092 |                 |         |
| COLLECTION DEVICE | 25 mm MCE Filter Cassette Collection Area = 385 sq mm<br>Field Area = 0 00785 sq mm                               |                 |         |

SAMPLE WERE COLLECTED BY J ENANG

SUMMARY OF ANALYSIS

| CLIENT<br>SAMPLE # | SAMPLE<br>LOCATION           | VOLUME<br>(LITERS) | FIBERS/<br>sq mm | FIBERS/<br>cc |
|--------------------|------------------------------|--------------------|------------------|---------------|
| 001                | BASEMENT MIDDLE              | 1800               | 2 548            | < 003         |
| 002                | BOILER ROOM BY SWITCH BOX    | 1800               | 3 185            | < 003         |
| 003                | BOILER ROOM MIDDLE           | 1800               | 1 274            | < 003         |
| 004                | 1ST FLOOR BY COPIER MACHINE  | 1800               | 1 911            | < 003         |
| 005                | 1ST FLOOR 10FT OF SOUTH WALL | 1800               | 5 732            | < 003         |
| 006                | 1ST FLOOR 13FT OF NORTH WALL | 1800               | 1 274            | < 003         |
| 007                | FIELD BLANK                  |                    | 0 000            |               |

NOTES 10 fibers/100 fields was used to calculate the lower limit of quantification (LOQ) Results below the LOQ have no statistical validity  
Samples were not collected by WKP Laboratories Inc  
The Federal EPA Clearance Criteria following an asbestos abatement project is 0 010 fibers/cc  
PCM air samples will be disposed of after 3 months unless otherwise directed by client in writing

LABORATORY ANALYST

LABORATORY DIRECTOR

CITY\_21MC100\_002833174