NYC 9/11 Public Portal Document

AMBIENT LABS, INC.
159 WEST 25TH STREET
NEW YORK, NY 10001

BULK SAMPLE LABORATORY DATA REPORT

PROJECT : O211512
CLIENT : Lehman Brothers
LOCATION : 1 WFC & 3 WFC
TECHNICIAN : PETE SCHORK

COLLECTED : 10/30/2001
DATE REC'D : 10/31/2001
TIME REC'D : 3:41 PM
ANALYZED : 10/31/2001

BATCH ID : 3409

SIGNED FOR AMBIENT LABS INC. BY:

Tarek Fato

LABORATORY ID NUMBER	FIELD ID NUMBER	SAMPLE COLOR	SAMPLE DESCRIPTION	ASBESTOS PRESENT	PERCENTOF TOTAL ASBESTOS		SAMPLE CONSTIUTENTS	
B2K91553	6-01	Gray	ON THE 6TH FLOOR SEE DRAWING.	YES	5.00 %	(P)	CHRYSOTILE :	5.00 %
							CELLULOSE :	20.00 %
							MINERAL WOOL :	40.00 %
							NON-FIBROUS :	35.00 %
B2K91554	6-02	Gray	ON THE 6TH FLOOR SEE DRAWING.	NAD	0.00 %	(P)	CELLULOSE :	10.00 %
							MINERAL WOOL :	60.00 %
							NON-FIBROUS :	30.00 %
B2K91555	6-03	Gray	ON THE 6TH FLOOR SEE DRAWING.	NAD	0.00 %	(P)	CELLULOSE :	20.00 %
							MINERAL WOOL :	40.00 %
							NON-FIBROUS :	40.00 %
B2K91556	7-01	Gray	ON THE 7TH FLOOR SEE DRAWING.	YES	2.00 %	(P)	CHRYSOTILE :	2.00 %
							CELLULOSE :	30.00 %
							MINERAL WOOL :	30.00 %
							NON-FIBROUS :	38.00 %
B2K91557	7-02	Gray	ON THE 7TH FLOOR SEE DRAWING.	YES	0.24 %	(P)	CHRYSOTILE :	TRACE
							CELLULOSE :	30.00 %
							MINERAL WOOL :	40.00 %
							NON-FIBROUS :	30.00 %
B2K91558	7-03	Gray	ON THE 7TH FLOOR SEE DRAWING.	YES	1.30 %	(P)	CHRYSOTILE :	1.30 %
							CELLULOSE :	30.00 %
							MINERAL WOOL :	40.00 %
							NON-FIBROUS :	28.70 %

NAD = No Asbestos Detected. Trace < 0.25 %.
(P) Analysis by Polarized Light Microscopy (PLM) NYS ELAP method 198.1 or EPA/600/R-93/116. (T) Analysis by Transmission Electron Microscopy (TEM) NYS ELAP method 198.4. Polarized Light Microscopy is not consistently reliable in detection of asbestos in floor coverings and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos containing. No reproduction of all or any portion of this report shall occur without written approval of Ambient Labs, Inc. All results disclosed in this report relate only to the items tested.
NVLAP ID # 101618. NYS ELAP ID # 10865. STATE OF CA ELAP ID # 2139.

CITY_21MC100_002840042

NYC-WTC_000220287