ENVIRO-PROBE, INC.
2917 Bruckner Boulevard - Bronx, New York 10461
Phone: (718) 863-0045 - Fax: (718) 518-7454

BULK MATERIAL ANALYSIS FOR ASBESTOS

TEST METHOD - POLARIZED LIGHT MICROSCOPY - EPA/600/R-93/116, July 1993
NATIONAL VOLUNTARY LABORATORY ACCREDITATION PROGRAM LAB ID# 101222
NEW YORK STATE ENVIRONMENTAL LABORATORY APPROVAL PROGRAM LAB ID# 10898

CLIENT NAME Central Env. Services
COMPANY
ADDRESS
CITY,STATE, ZIP

DATE SUBMITTED: 9/24/01
DATE ANALYZED: 9/24/01
DATE REPORTED: 9/26/01
LAB FILE # 23312
ANALYST S K. Dewan

1. SAMPLING LOCATION	**67/69 Wall St., NY. Various Floors**					
2. CLIENT'S ID#	37	38				
3. LAB ID# B01-	20309	20310				
4. STEREO-MICROSCOPIC EXAMINATION						
1. HOMOGENEOUS (Y/N)	**N**	**N**				
2. COLOR	**1 & 4**	**1 & 4**				
1. WHITE						
2. BROWN						
3. GRAY						
4. OTHERS						
5. ASBESTOS DETECTED (YES/NO)	N	N				
6. ASBESTOS PERCENTAGE						
1. AMOSITE						
2. CHRYSOTILE						
3. CROCIDOLITE						
4. OTHERS						
7. TOTAL ASBESTOS PERCENTAGE	0	0				
8. PERCENTAGE - OTHER FIBROUS MATERIALS						
1. CELLULOSE						
2. FIBROUS GLASS	15	20				
3. OTHERS	30	25				
9. NON-FIBROUS MATERIALS						
1. CARBONATES	15	15				
2. SILICATES	10	15				
3. OTHERS	30	25				
10. TOTAL	**100**	**100**				

This report shall not be reproduced except in full, without the written approval of the laboratory

For quantitation purposes 1% is the concentration at which there is an uncertainty

These results apply to these/this particular samples/sample

o This report is not endorsed by NVLAP or any other U.S Government Agency

... Traces = < 1%

LAB DIRECTOR/SUPERVISOR'S SIGNATURE

CITY_21MC100_002388393