

ambient labs inc. 159 West 25th Street New York, NY 10001 ELAP #10865

REPORT OF AIR SAMPLE ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

Project ID : 0211366

Client Name : The Otto Gerdau Company, BAI Group

Project Name : 80-82 Wall Street

Field ID : 211366-01

Sample ID : AEM990 09400

Date Received : 9/20/01

Sample Description : 12th Floor: (Mitchell/Martin) Conference Room

Filter Composition : MCE

Porosity : 0.45 micron

Filt Lot # : EX66

Filter Diameter : 25 mm Effective Filter Area : 385 mm² Air Volume : 1365 ltrTotal Filter Area Analyzed : 0.0630 mm²

Grid Openings : 7

Avg Grid Opening Area : 0.0090 mm²

Grid Lot # : 4083

Analytical Sensitivity : 0.0045 asbestos struct/cm³**Number of Asbestos Structures :**

Chrysotile : 0

Amphibole : 0

Number of Structure Types :

LENGTH	FIBER	CLUSTER	MATRIX	BUNDLE
0.5 um < L < 5 um	0	0	0	0
L > 5 um	0	0	0	0

A: TOTAL CHRYSOTILE STRUCTURE CONCENTRATION : LT ANYL SENS structure/cm³B: TOTAL AMPHIBOLE STRUCTURE CONCENTRATION : LT ANYL SENS structure/cm³C: TOTAL ASBESTOS STRUCTURE (A+B) CONCENTRATION : LT ANYL SENS structure/cm³

TOTAL ASBESTOS CONCENTRATION :	IN AIR	LT ANYL SENS	structure/cm ³
	ON FILTER	LT ANYL SENS	structure/mm ²

Micrograph ID # for Reported Structures: None

None

Reported for Ambient Labs Inc. by :



Analysis Date : 9/20/01

INNA NURIK

Environmental Analyst

* Overloaded, NA - Analyzed