

ambient labs inc. 159 West 25th Street New York, NY 10001 ELAP #10865

REPORT OF AIR SAMPLE ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

Project ID : **O211658**
 Client Name : **Jack Resnick & Sons, Inc.**
 Project Name : **75 Park Place** Field ID : **2971-01**

Sample ID : **AEM990 11005** Date Received : **11/14/01**
 Sample Description :

Filter Composition : Porosity : **0.45** micron Filt Lot # :
 Filter Diameter : **25** mm Effective Filter Area : **385** mm² Air Volume : **1820** ltr
 Total Filter Area Analyzed : **0.0450** mm²

Grid Openings : **5** Avg Grid Opening Area : **0.0090** mm² Grid Lot # : **4083**
 Analytical Sensitivity : **0.0047** asbestos struct/cm

Number of Asbestos Structures :
 Chrysotile : **0**
 Amphibole : **0**

Number of Structure Types :
 LENGTH FIBER CLUSTER MATRIX BUNDLE
 0.5 um < L < 5 um
 L > 5 um

A: TOTAL CHRYSOTILE STRUCTURE CONCENTRATION : **LT ANYL SENS** structure/cm³
 B: TOTAL AMPHIBOLE STUCTURE CONCENTRATION : **LT ANYL SENS** structure/cm³
 C: TOTAL ASBESTOS STUCTURE (A+B) CONCENTRATION : **LT ANYL SENS** structure/cm³

TOTAL ASBESTOS CONCENTRATION :	IN AIR	LT ANYL SENS	structure/cm ³
	ON FILTER	LT ANYL SENS	structure/mm ²

Micrograph ID # for Reported Structures:

Reported for Ambient Labs Inc. by :

Tarek Fata

Analysis Date : **11/14/01**

TAREK FATA
 Environmental Analyst

* Overloaded, NA - Analyzed