


TEM Asbestos (air) Count Sheetsample area
analyzed**Client Name:** R.K.M. Inc.**Job #:** 201111306**Lab Sample #:** 03**Client Sample #:** 110201TD03**Received:** 11/03/2001

12:45:00

Date Analyzed: 11/05/2001**Scope #:****Volume (liters):** 1 500.0**Filter Type / Filter Area:** MCE 385 mm2**Grid Opening Size:** 0.01000**Area Examined:** 0.06000 mm2**Magnification:** 20,000**Accelerating Voltage:** 100 KeV

Analysis Performed by:

Mikhail Gruzman

Location	Grid Opening	Fiber	Length μM	Width μM	Fiber Type	Morphology	EDS	Orient	SAED	Photo
A3-B4/1	1	NSD							☐	
A3-C4/1	2	NSD							☐	
A3-E4/1	3	NSD							☐	
A3-F4/1	4	NSD							☐	
A4-E4/1	5	NSD							☐	
A4-F4/1	6	NSD							☐	

NSD: No Asbestos Structures Detected

Comments

	Structure Density (str/mm2)	Concentration (str/cc air)	Grid Evaluation
Total Grid Openings: 6			
Chrysotile Asbestos Structures: 0	<16.7	<0.0043	☒ Grid Openings Covered > 50%
Amphibole Asbestos Structures: 0	<16.7	<0.0043	☒ Intact Grid Opening > 50%
Asbestos Structures ≥ 5 microns: 0	<16.7	<0.0043	☒ Undissolved Filter < 10%
Total Non-Asbestos Structures:			☒ Folded Replica < 50%
Total Asbestos Structures: 0	<16.7	<0.0043	☒ Filter Loading < 10%
Analytical Sensitivity: 16.7		0.0043	☒ Particulate Even