



47 Hudson Street, Ossining, New York 10562
 Tel: (914)-762-9000 • Fax: (914)-762-9638 • testwelllabs.com

Offices in

Albany, NY
 Queens, NY
 Woodbridge, NJ
 Miami, FL

**CERTIFICATE OF LABORATORY ANALYSIS FOR ASBESTOS
 CONTENT**

Transmission Electron Microscopy Results (TEM)

Certifications &
 Accreditations



Apartment #: 3C Result: <16.53 Structures per mm²

Date Collected: 12/5/01 Date of Analysis: 12/10/01

Medium: Air Analytical Method: AHERA EPA 40 CFR Part 763



According to the US EPA (40 CFR 763, Appendix A to Subpart E -
 - *Interim Transmission Electron Microscopy Analytical Methods --
 Mandatory and Nonmandatory -- and Mandatory Section to
 Determine Completion of Response*), the level of concern for
 asbestos is based on continuous exposure to more than 70
 structures per square millimeter for an extended period of time.



This report is the confidential property of our clients. This certificate of analysis/report shall not be used
 by the client to claim product endorsement by National Voluntary Laboratory Approval Program
 (NVLAP) or any agency of the United States Government. This certificate of analysis/report shall not be
 reproduced in full, without the written approval of Testwell Laboratories, Inc.

Copyright © 2001 Testwell Laboratories, Inc.

NYS DOH ELAP #10871.
 11142 & 11651


 Deborah McCarl-Laboratory Director

