


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8TIME 800LOCATION PS89M DATE 4/19/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
South Exit		72.3	53.2	521	3	58	0
SE Corner		72.0	53.0	528	3	~~69~~ 115	0
East Side		71.7	52.9	530	3	122	0
NE Corner		71.6	52.5	523	3	118	0
North Exit		71.3	52.6	519	3	116	0
NW Corner		71.1	52.8	506	3	69	0
By Air Intake		70.8	52.4	510	3	73	0
SW Corner		70.5	52.1	515	3	64	0
Playground N		70.3	51.8	518	3	^{7:40} 99 / ^{8:05} 64	0
Playground S		70.0	51.4	520	3	^{7:40} 106 / ^{8:05} 65	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 4/19/02


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 8TIME 830LOCATION PS89MDATE 4/19/02PROJECT NO. 19125-297

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Cafeteria		70.6	48.5	584	3	45	0
Dance Rm.		71.8	48.0	576	3	30	0
Hall by Cafeteria		71.8	51.6	579	3	50	0
North Exit		71.9	51.7	588	3	51	0
Hall by Stair 1		70.6	51.0	591	3	51	0
132A		70.5	51.2	620	3	34	0
132B	2	70.7	51.4	617	3	34	0
132C		70.6	51.4	613	3	30	0
132D		70.5	51.2	608	3	27	0
South Exit		72.0	51.0	580	3	50	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 4/19/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 8


TIME 900

LOCATION PS89M DATE 4/19/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
501	30	72.0	49.2	750	3	35	0
502	1	72.2	48.8	812	3	29	0
Hall by Stair 3	3	72.4	49.4	772	3	40	0
504	34	73.3	50.1	1120	3	39	0
506	35	73.8	50.6	1105	3	35	0
515		72.9	47.7	635	3	40	0
508		74.1	47.4	667	3	48	0
510 (Hall)		74.2	48.1	617	3	50	0
512	1	74.3	48.0	631	3	37	0
Hall by Stair 2	-	75.1	48.0	610	3	50	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 4/14/02

CITY_21MC100_002886636


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 8TIME 930LOCATION P589 M DATE 4/19/02 PROJECT NO. 19125-297

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
526	28	74.7	49.2	1357	3	32	0
528	30	75.2	49.6	750	3	40	0
517	2	73.5	46.7	625	3	42	0
530 (Hall)	-	73.2	46.9	609	3	50	0
532	32	74.6	50.7	1034	3	30	0
519	11	74.6	47.1	975	3	42	0
Hall by Stair 1		74.5	47.2	780	3	46	0
Stair 1		75.3	47.4	710	3	45	0
419 E	4	74.5	46.2	690	3	30	0
432 (Hall)		74.2	46.6	720	3	32	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 4/19/02

CITY_21MC100_002886637

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8

TIME 1000LOCATION PS89M DATE 4/19/02 PROJECT NO. 19125-297

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
432	18	75.1	48.7	971	3	25	0
430	19	75.1	47.8	758	3	37	0
428 (Hall)		74.7	47.0	744	3	43	0
426		75.1	47.5	599	3	40	0
Hall by Stair 2		74.8	46.5	623	3	49	0
410 (Hall)		74.7	45.7	600	3	49	0
408 (Hall)		74.8	45.5	626	3	47	0
Hall by Elevator		75.0	46.0	637	3	49	0
404	31	75.7	47.7	1081	3	35	0
402	32	75.3	48.3	1432	3	39	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jing Chen Date: 4/19/02


CITY_21MC100_002886638

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 8TIME 1030LOCATION PS89M DATE 4/19/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
301	21	69.9	53.3	756	2	33	0
301 (Hall)		71.4	54.2	744	2	42	0
302	14	74.2	55.1	882	2	32	0
Hall by Elevator		73.6	53.6	816	2	42	0
304	14	74.4	53.8	856	2	41	0
306	18	75.5	52.2	830	2	35	0
307 (Hall)		74.1	49.1	747	2	50	0
315		72.8	46.0	712	2	47	0
315 (Hall)		74.4	49.2	773	2	40	0
308 (Hall)		74.2	49.2	770	2	41	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 4/19/02

CITY_21MC100_002886639


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8

TIME 1100LOCATION PS89 M DATE 4/19/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
308		73.1	46.9	719	3	34	0
310	2	74.0	49.5	769	3	38	0
314 (Hall)		73.6	48.2	701	3	50	0
316 (Hall)	—	73.4	48.5	723	3	49	0
Hall by Stair 2		73.3	48.7	697	3	49	0
326	17	74.5	50.1	784	3	35	0
328	15	76.0	53.1	829	3	51	0
330	17	75.7	50.9	807	3	37	0
332	18	76.0	51.0	818	3	39	0
319	4	76.3	49.0	749	3	46	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 4/19/02

CITY_21MC100_002886640


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8TIME 1130LOCATION P589 M DATE 4/19/02 PROJECT NO. 19125-297

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
219	19	75.4	46.7	1406	3	20	0
232		75.1	49.5	764	3	38	0
230 (Hall)	—	74.7	47.5	680	3	46	0
217C (Hall)	—	74.8	47.7	689	3	47	0
228	25	75.2	50.6	963	3	40	0
226	22	76.0	49.4	986	3	30	0
208 (Hall)		74.1	46.9	633	3	46	0
Auditorium		73.8	46.5	620	3	40	0
204	20	74.6	46.6	846	3	30	0
202	43	77.2	50.0	1208	3	33	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 4/19/02

CITY_21MC100_002886641