

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 3/8/02 9:00:00 PM
 ATC Group #: 6990
 Analysis Date: 3/9/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC BOE H.S. For Leadership & Public Services

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
12 6990 -9	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 6990 -10	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
14 6990 -11	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
15 6990 -12	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 6990 -13	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
17 6990 -14	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
18 6990 -15	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
19 6990 -16	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
20 6990 -17	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
21 6990 -18	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002389076